

## LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	N	M	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE      DOCKET NUMBER      EVENT DATE      REPORT DATE

0	1	L	6	0	5	0	0	0	2	2	0	7	0	6	2	3	8	3	8	0	7	2	2	8	3	9
7	8	60	61								68	69						74	75						80	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | Two monthly surveillance tests on the Inadequate Core Cooling-Accident Level Monitor, 1  
0 3 | installed per NUREG 0737, Item II.F.2, were missed during the period immediately 1  
0 4 | following its installation on December 31, 1981, until the 1982-1983 shutdown. 1  
0 5 | Consequences were minimal since a preoperational test was performed on the monitor 1  
0 6 | before being put into service. The monitor was tested prior to startup from the 1  
0 7 | 1982-1983 shutdown, when it was found to be properly calibrated and functional. 1

$\begin{array}{|c|c|} \hline 5 & 8 \\ \hline \end{array}$

7 8 9 10 11 12 13 14 15 16

(17) LER/RO REPORT NUMBER 83 —

EVENT YEAR 019 /

SEQUENTIAL REPORT NO. 03 —

OCCURRENCE CODE L —

REPORT TYPE 0

REVISION NO.

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER				
G	18	Z	19	Z	20	Z	21	0	0	0	0	22	N	23	N	24	N	25	G	0	8	0
33		34		35		36		37				40	41		42		43		44			47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Procedures for the surveillance have been generated and the surveillance has been

1 1 added to the schedule.

1 2 \_\_\_\_\_

1	3	
---	---	--

1 4 7 8 9 80

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)

1 5 E 1 0 0 NA A Review of Procedures

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 2 33 4 34 NA NA

7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES		TYPE		DESCRIPTION
NUMBER				
1	7	0	0	0
		37	0	38
				NA

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

8 9 11 12  
LOSS OF OR DAMAGE TO FACILITY (43)  
TYPE DESCRIPTION  
1 9 Z (42) NA  
S PDR

8308090045 830722  
PDR ADOCK 05000220  
S PDR

2 0 N 44 NA

NRC USE ONLY

NAME OF PREPARER

D.T. Kesel

PHONE: (315) 349-2611

July 25, 1983

Dr. Thomas E. Murley  
Regional Administrator  
United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

RE: Docket No. 50-220  
LER 83-19

Dear Dr. Murley,

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specifications, we hereby submit the following Licensee Event Report:

83-19      which is being submitted in accordance with Section 6.9.2(b)3, observed inadequacies in the implementation of administrative or procedural controls which threaten to cause reduction of degree of redundancy provided in reactor protection systems or engineered safety systems.

This report was completed in the format designated in NUREG-0161, dated July 1977.

Very truly yours,

*Thomas E. Lempges*

Thomas E. Lempges  
Vice President  
Nuclear Generation

TEL/jm

Attachments (3 copies)

cc: Director, Office of I&E (30 copies)  
Director, Office of MIPC (3 copies)

IE22  
11