

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE: (717) 542-2181 Ex. 3759

8308090324 830725
PDR ADOCK 05000387
S PDR



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

July 25, 1983

Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-098/03L-0
ER 100450 FILE 841-23
PLA-1761

Dear Dr. Murley:

Attached is Licensee Event Report No. 83-098/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that, with the unit in Operational Condition 3, one of the suppression pool-to-drywell vacuum breakers was considered inoperable based on dual status indication (simultaneous open and closed position indication) in the main control room.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE22
11