

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

August 1, 1983
LOZ-83-0092

J. WILLIAMS, JR.
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM M-72, LACK OF QA PROGRAM
FOR FIRE PROTECTION SYSTEM INSTALLATION
W.O. 57300, JOB E-5590, FILE NO. 956C, M-72

This letter constitutes an interim report concerning the subject condition initially reported to the Commission as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

The actions described in interim report, LOZ-83-0022, dated April 29, 1983, are continuing. First, The Cincinnati Gas & Electric Company (CG&E) Nuclear Engineering and Quality Assurance Departments are formulating a quality assurance program to clearly define how each of the commitments made to BTB-APCSB 9.5-1, Appendix A, Part C, Quality Assurance, will be implemented for future fire protection work.

Second, the Nuclear Engineering and Quality Assurance Departments, in conjunction with Sargent & Lundy, are continuing their efforts to develop a program to verify the quality of the design, installation, and testing of existing fire protection systems.

A projected completion date for any required corrective actions, will be determined upon completion of the above tasks. A follow-up report on the status of these actions will be submitted by November 10, 1983.

AUG 04 1983


IE27
10

Mr. J.G. Keppler
Regional Administrator
August 1, 1983
LOZ-83-0092
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
J. WILLIAMS, JR.
SENIOR VICE PRESIDENT

RNT/MJM/sfr

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
ATTN: W.F. Christianson
NRC Zimmer Project Inspector, Region III
ATTN: E. R. Schweibinz