



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

August 19, 1983

Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-107/01P-0
ER 100450 FILE 841-23
PLA-1802

Docket No. 50-387
License No. NPF-14

Dear Dr. Murley:

This transmission confirms the telephone report of August 19, 1983, by A.P. Piemontese to E.C. McCabe of your staff, regarding the Emergency Service Water (ESW) system. During a maintenance activity, the ESW "A" Loop Discharge to Spray Pond Valve would only travel in the closed direction. The subject valve is manually operated and normally throttled. When the valve could not be operated in the open direction, the ESW Loop and associated Emergency Core Cooling Systems (ECCS) were declared inoperable at 1155. Mechanical stops were loosened which permitted the valve to be opened to the proper position. The system was tested and declared operable at 1245.

This condition is considered reportable in accordance with Technical Specification 6.9.1.8.b, and additional information regarding circumstances of the incident and corrective actions to be taken will be provided in the fourteen day follow-up report.

H.W. Keiser

APP/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8309070084 830819
PDR ADOCK 05000387
S PDR

IE 29
11/0