

OPERATING DATA REPORT (JUNE REVISION)

DOCKET NO. 50-336
 DATE _____
 COMPLETED BY J. Gibson
 TELEPHONE (203) 447-1791
 Ext. 4431

OPERATING STATUS

1. Unit Name: Millstone 2
2. Reporting Period: June 1983 (Revision)
3. Licensed Thermal Power (Mwt): 2700
4. Nameplate Rating (Gross MWe): 909
5. Design Electrical Rating (Net MWe): 870
6. Maximum Dependable Capacity (Gross MWe): 895*
7. Maximum Dependable Capacity (Net MWe): 864*
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7)
 Since Last Report, Give Reasons:
N/A

Notes: Items 21 and 22 cumulative are weighted ave. unit operated at 2560 MW thermal prior to its uprating to its current 2700 MW thermal power level.

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	4343	65855
12. Number Of Hours Reactor Was Critical	0	3130.5	48365.3
13. Reactor Reserve Shutdown Hours	0	0	2205.5
14. Hours Generator On-Line	0	2994.9	46182.2
15. Unit Reserve Shutdown Hours	0	0	468.2
16. Gross Thermal Energy Generated (MWH)	0	7877464	13171669
17. Gross Elec. Energy Generated (MWH)	0	2575530	37806378
18. Net Electrical Energy Generated (MWH)	(-3011)**	2471358.3**	36233171**
19. Unit Service Factor	0	69.0	70.1
20. Unit Availability Factor	0	69.0	70.8
21. Unit Capacity Factor (Using MDC Net)	0	65.9*	65.9*
22. Unit Capacity Factor (Using DER Net)	0	65.4	65.0*
23. Unit Forced Outage Rate	0	13.7	19.1
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Continuation of Refuel/Maintenance Outage			

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	N/A	N/A
INITIAL ELECTRICITY	N/A	N/A
COMMERCIAL OPERATION	N/A	N/A

* Incorrect MDC gross and MDC net values were used.

** Corrects math error in original June report.

8309080115 830815
 PDR ADOCK 05000336
 PDR
 R