

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	2	8	7	0	8	0	5	8	3	8	0	9	0	2	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

SECRET NUMBER

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 7 | Unit 2 in mode 6 (refueling). During routine ice weighing per SI-106, the
0 3 | group 1 (bays 1-8) row 1 average ice basket weight was found below the 1200
0 4 | lb/basket minimum. Bays 1 and 2 average basket weight was also found below the
0 5 | 1200 lb/basket minimum and 20 additional baskets were found to weigh below 1200 lbs.
0 6 | This condition may have existed in modes 1-4 and required entry into LCO 3.6.5.1.
0 7 | There was no effect upon public health and safety. Previous occurrences - one
0 8 | (SQRO-50-327/82130).

0 9		SYSTEM CODE S B		CAUSE CODE X		CAUSE SUBCODE Z		COMPONENT CODE H T E X C H				COMP. SUBCODE D		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
LER/RO REPORT NUMBER 18 3		EVENT YEAR 8 3		SEQUENTIAL REPORT NO. 1 0 7		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN X		FUTURE ACTION X	
22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	
EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER N		CAUSE DESCRIPTION AND CORRECTIVE ACTION W 1 2		37	
37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The lowest of the unacceptable results was 1169 lbs. The primary cause was

1 1 sublimation of ice in the crane wall area where rows 1 and 2 are located. Unit 2

1 2 is presently in mode 6 and ice is being added in these areas. SI-106 will be

1 3 performed again prior to entering mode 4. All other ice condenser operability

1 4 requirements were met. No additional corrective action is required.

FACILITY STATUS (1) 5 (2) H (28) 0 0 0 (29) 0 0 0 (30) NA
 METHOD OF DISCOVERY (31) B (32) Surveillance test
 ACTIVITY CONTENT RELEASED OF RELEASE (33) Z (34) Z (35) NA
 AMOUNT OF ACTIVITY (36) NA
 PERSONNEL EXPOSURES NUMBER (37) 0 0 0 (38) Z (39) NA
 PERSONNEL INJURIES NUMBER (40) 0 0 0 (41) NA
 LOSS OF OR DAMAGE TO FACILITY TYPE (42) Z (43) NA
 PUBLICITY ISSUED (44) N (45) NA
 8309090342 830902
 PDR ADOCK 05000328
 S PDR
 NRC USE ONLY

Name of Preparer: G. B. Kirk /M. R. Harding

Phone: (615) 870-6422

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower 11

USNRC REGION II
ATLANTA, GEORGIA

03 SEP 6 09:48

September 2, 1983

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 2 - DOCKET
NO. 50-328 - FACILITY OPERATING LICENSE DPR-79 - REPORTABLE OCCURRENCE
REPORT SQRO-50-328/83107

The enclosed report provides details concerning the minimum average ice weight per basket being less than the required 1,200 pounds in the group 1 row 1 baskets. This report is submitted in accordance with Sequoyah unit 2 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, NUC PR, Sequoyah

OFFICIAL COPY

TC 221
1/1