



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 30, 1983

JAMES P. McGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
License No. NPF-13  
Docket No. 50-416  
File 0260/15525/15526  
Revised Response to Violation  
Notice 416/83-10-02  
AECM-83/0384

Reference: AECM-83/0351, dated 6/10/83

The above referenced letter provided MP&L's response to the subject Violation Notice. That response is revised as follows:

Substitute the following for Sections III, IV, and V:

III. THE CORRECTIVE STEPS WHICH HAVE BEEN TAKEN AND THE RESULTS ACHIEVED

Material Nonconformance Report (MNCR) 0171-83 has been written to document this quality related deficiency. Plant Administrative Procedure 01-S-06-20, "Receiving, Loading, and Removal of Neutron Sources", has been revised in order to establish programmatic controls for assuring that the auxiliary hoist is raised to a height sufficient to allow a neutron source to clear the reactor vessel flange.

IV. CORRECTIVE STEPS WHICH WILL BE TAKEN TO AVOID FURTHER VIOLATIONS

The above discussed corrective actions are considered sufficient.

8309090508 830901  
PDR ADOCK 05000416  
Q PDR

Member Middle South Utilities System

83 JUL 7 AIO: 57

USNRC REGION 3  
ATLANTA, GEORGIA

Mr. J. P. O'Reilly  
NRC

AECM-83/0384  
Page 2

V. THE DATE WHEN FULL COMPLIANCE WILL BE ACHIEVED

Full compliance will be in effect prior to the next source movement.

Yours truly,

*L. A. DeYoung*  
*for J. P. O'Reilly*

JPM:jh

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555