

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJMF1 00-000000-00 41111 5
7 8 9 14 15 25 26 30 37 CAT 52

CONT

01 REPORT SOURCE L 05000348 080283 083183 9
7 8 40 41 48 49 56 57 64 65 72 73 79 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1025 on 8/2/83, the 1A Post LOCA Hydrogen Recombiner was declared inoperable
03 due to a failed temperature indicator. Tech. Spec. 3.6.4.2 requires this re-
04 combiner to be operable. Tech. Spec. 3.6.4.2 action statement requirements were
05 met. Health/safety of the public was not affected.

06

07

08

09 SYSTEM CODE SE 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE RECOMB 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 83 21 22 23 24 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event was caused by the failure of the temperature indicator. A new indica-
11 tor was installed and following satisfactory completion of FNP-1-STP-223.1
12 (Electric Hydrogen Recombiner 1A Calibration), 1A Post LOCA Hydrogen Recombiner
13 was declared operable at 2210 on 8/2/83.

14

15 FACILITY STATUS E 28 100 29 NA 30 METHOD OF DISCOVERY A 31 Operator Observation 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

17 PERSONNEL EXPOSURES NUMBER 000 37 Z 38 NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

18 PERSONNEL INJURIES NUMBER 000 40 NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

20 PUBLICITY ISSUED N 44 NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156