



**Entergy  
Operations**

Entergy Operations, Inc.

Route 3, Box 1370

Ft. Smith, AR 72801

Tel: 501-964-3100

December 17, 1990

1CAN129006


U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Stop P1-137  
Washington, D.C. 20555

SUBJECT: Arkansas Nuclear One - Unit 1  
Docket No. 50-313  
License No. DPR-51  
Monthly Operating Report

Gentlemen:

The Arkansas Nuclear One - Unit 1 Monthly Operating Report for  
November, 1990 is attached.

Very truly yours,

  
James J. Fisicaro  
Manager, Licensing

JJF/SAB/mmg  
Attachment

9012210045 901130  
PDR ADOCK 05000313  
P PDR

2100

TERA

cc: Mr. Robert D. Martin  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

NRC Senior Resident Inspector  
Arkansas Nuclear One - ANO-1 & 2  
Number 1, Nuclear Plant Road  
Russellville, AR 72801

Mr. Thomas W. Alexion  
NRR Project Manager, Region IV/ANO-1  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 11-B-19  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

Ms. Sheri Peterson  
NRR Project Manager, Region IV/ANO-2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 11-B-19  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

# OPERATING DATA REPORT

DOCKET NO: 50-313  
 DATE: November, 1990  
 COMPLETED BY: D. A. Schaubroeck  
 TELEPHONE: (501) 964-3743

## OPERATING STATUS

1. Unit Name: Arkansas Nuclear One - Unit 1
2. Reporting Period: November 1-30, 1990
3. Licensed Thermal Power (MWt): 2,568
4. Nameplate Rating (Gross MWe): 902.74
5. Design Electrical Rating (Net MWe): 850
6. Maximum Dependable Capacity (Gross MWe): 883
7. Maximum Dependable Capacity (Net MWe): 836
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: \_\_\_\_\_
9. Power Level To Which Restricted. If Any (Net MWe): 80%
10. Reasons For Restrictions. If Any: A license amendment was issued limiting operation to 80% due to a newly identified wall break LOCA in the High Pressure Injection (HPI) Line Piping.

	MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period ....	720.0	8,016.0	139,819.0
12. Number of Hours Reactor was Critical .....	0.0	6,477.2	97,688.4
13. Reactor Reserve Shutdown Hours .....	0.0	0.0	5,044.0
14. Hours Generator On-Line .....	0.0	6,438.8	95,738.7
15. Unit Reserve Shutdown Hours ..	0.0	0.0	817.5
16. Gross Thermal Energy Generated (MWH) .....	0.0	13,031,662.0	215,056,117.0
17. Gross Electrical Energy Generated (MWH) .....	0.0	4,371,220.0	71,423,695.0
18. Net Electrical Energy Generated (MWH) .....	-2,890.0	4,129,838.0	67,842,088.0
19. Unit Service Factor .....	0.0	80.3	68.5
20. Unit Availability Factor .....	0.0	80.3	69.1
21. Unit Capacity Factor (Using MDC Net) .....	-0.5	61.6	58.0
22. Unit Capacity Factor (Using DER Net) .....	-0.5	60.6	57.1
23. Unit Forced Outage Rate .....	0.0	1.6	13.1
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>1R9 Refueling Outage which began October 1990; the scheduled date for restart is December, 1990.</u>			
25. If Shut Down At End of Report Period. Estimated Date of Startup: <u>December 20, 1990</u>			
26. Units in Test Status (Prior to Commercial Operation):			

Forecast      Achieved

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-313  
 UNIT: One  
 DATE: November, 1990  
 COMPLETED BY: D. A. Schaubroeck  
 TELEPHONE: (501) 964-3743

MONTH November, 1990

DAY            AVERAGE DAILY POWER LEVEL  
                  (MWe-Net)

1 .....	-4
2 .....	-4
3 .....	-4
4 .....	-4
5 .....	-4
6 .....	-4
7 .....	-4
8 .....	-4
9 .....	-4
10 .....	-4
11 .....	-4
12 .....	-4
13 .....	-4
14 .....	-4
15 .....	-4
16 .....	-4
17 .....	-4
18 .....	-4
19 .....	-4
20 .....	-4
21 .....	-4
22 .....	-4
23 .....	-5
24 .....	-3
25 .....	-3
26 .....	-5
27 .....	-5
28 .....	-5
29 .....	-5
30 .....	-5

AVGS: -4

## INSTRUCTION

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

NRC MONTHLY OPERATING REPORT

OPERATING SUMMARY

NOVEMBER, 1990

UNIT ONE

---

Unit One was off line the entire month for the 1R9 refueling outage.

UNIT SHUTDOWNS AND POWER REDUCTIONS  
REPORT FOR NOVEMBER, 1990

DOCKET NO. 50-313  
UNIT NAME One  
DATE November, 1990  
COMPLETED BY D. A. Schaubroeck  
TELEPHONE (501) 964-3743

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
90-09	901101	S	720	C	4	N/A	ZZ	ZZZZZZ	The unit was off line the entire month for the 1R9 Refueling Outage.

<sup>1</sup>  
F: Forced  
S: Scheduled

<sup>2</sup>  
Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training &  
License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

<sup>3</sup>  
Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Continuation  
5-Load Reduction  
9-Other

<sup>4</sup>  
Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets for Licensee  
Event Report (LER) File (NUREG-  
1022)

<sup>5</sup>  
Exhibit I - Same Source

DATE: November, 1990

### REFUELING INFORMATION

1. Name of facility: Arkansas Nuclear One - Unit 1
2. Scheduled date for next refueling shutdown. October, 1990
3. Scheduled date for restart following refueling. December, 1990

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? If answer is yes, what, in general, will there be? If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?

Technical Specification changes associated with ANO-1 Cycle 10 Reload Report have been submitted to the Nuclear Regulatory Commission.

5. Scheduled date(s) for submitting proposed licensing action and supporting information. The cycle 10 Reload Report has been submitted.
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

Debris resistant, extended solid end cap design fuel rod will be used in the reload fuel batch. Also, an emergency Technical Specification was requested from the NRC allowing the replacement of one fuel rod in an assembly with one stainless steel filler rod. This fuel assembly is being reused during cycle 10 operation.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool. a) 177 b) 565
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.

present 968 increase size by 0

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

DATE: 1994 (Loss of fullcore offload capability)