

NSP

Regulatory

File Cys

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

August 29, 1977

Mr Victor Stello, Director
Division of Operating Reactors
c/o Distribution Services Branch, DDC, ADM
U S Nuclear Regulatory Commission
Washington, DC 20555



Dear Mr Stello:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 263 License No. DPR-22

Removal of Drywell-Wetwell
Differential Pressure Controls

On August 23, 1977 representatives of Northern States Power Company met with members of your staff to review progress of the Mark I Containment modifications at Monticello. We also addressed the NRC criteria for removal of differential pressure controls which were transmitted to us with a letter from Mr D K Davis, dated May 19, 1977. Enclosure (1) contains copies of the view graphs used during our presentation during the August 23 meeting.

During this meeting we were informed by your staff that to remove differential pressure controls we must either demonstrate compliance with the criteria in the May 19 letter or the loads must be less than code allowable. It is shown in Tables 2.2-2 and Tables 2.2-3 of enclosure (2) that at the maximum torus water level the strength ratios of all critical structural elements are either less than 0.5 or code allowable. The loads used to derive these ratios were determined in accordance with the information contained in the May 19 letter.

Since the Staff criteria for removal of differential pressure controls are satisfied at Monticello we hereby withdraw our License Amendment Request dated April 15, 1977 and our License Amendment Request dated November 5, 1976, which was superseded by the April 15 submittal, and the commitments contained in our March 1, 1976 letter to you on this subject. The amendment requests contained revisions to the Technical Specifications covering the drywell to suppression chamber differential pressure, containment water volume and differential pressure instrumentation.

For your information, we have provided the strength ratios of the critical structural elements at the maximum torus water level without delta-P and without the 1.33 multiplier. This information is contained in Tables 2.2-1a, 2.2-2a and 2.2-3a of enclosure (2), and demonstrates that all elements meet code allowable or are very close to it. The 1.33 multiplier was dropped for this case on the

NORTHERN STATES POWER COMPANY


Mr Victor Stello

Page 2

August 29, 1977

basis of the information presented to your staff by General Electric on August 24, 1977, which demonstrated that the pool swell loads from the one quarter scale test program are approximately 80% of the values reported in the Short Term Program Report.

Yours very truly,

A handwritten signature in cursive script, appearing to read "L O Mayer for".

L O Mayer, PE

Manager of Nuclear Support Services

LOM/LLT/ak

cc: J G Keppler

G Charnoff

MPCA - Attn: J W Ferman

UNITED STATES NUCLEAR REGULATORY COMMISSION

NORTHERN STATES POWER COMPANY

MONTICELLO NUCLEAR GENERATING PLANT

Docket No. 50-263

License No. DPR-22

LETTER DATED AUGUST 29, 1977
RESPONDING TO NRC REQUESTS
FOR INFORMATION ON CONTAINMENT DESIGN

Northern States Power Company, a Minnesota corporation, by this letter dated August 29, 1977 hereby submits information in response to NRC requests for information concerning the Mark I Containment.


This request contains no restricted or other defense information.

NORTHERN STATES POWER COMPANY

By *L. J. Wachter*
J. Wachter
Vice President, Power Production
& System Operation

On this 29th day of August, 1977, before me a notary public in and for said County, personally appeared L. J. Wachter, Vice President, Power Production and System Operation, and being first duly sworn acknowledged that he is authorized to execute this document on behalf of Northern States Power Company, that he knows the contents thereof and that to the best of his knowledge, information and belief, the statements made in it are true and that it is not interposed for delay.

Denise E. Halvorson



TORUS SUPPORT COLUMN CONNECTION

● PURPOSE OF REINFORCEMENT

- COMPLETE SUPPORT REINFORCEMENT CHAIN
- PIN CONNECTION AT BASE OF COLUMN AND
COLUMNS HAVE BEEN PREVIOUSLY
REINFORCED

● LOAD BASIS FOR STRENGTH RATIO CALCS.

- PLANT UNIQUE ANALYSIS REPORT
(SHORT TERM PROGRAM)
- POOL SWELL + DEAD LOAD + SEISMIC WΔP
IS COL. = 654.4K
OS COL. = 847.2K




Figure 2.2-2

REINFORCED SUPPORT COLUMN TO SHELL CONNECTION

TORUS SUPPORT CAPACITIES

COMPONENT	CODE ALLOWABLE	ULTIMATE	STRENGTH RATIO
SHELL CONNECTION	940K	2820K	0.30
COLUMN	1189K	3288K	0.26
PIN CONNECTION	993K	2960K	0.29

STP DOWNWARD LOAD W/ Δ P FOR O.S. COLUMN = 847K

SUMMARY

- INCREASED SIZE OF EXISTING WELDS TO FULLY DEVELOP STRENGTH OF 1 1/2" WEB PLATE
- ADDED 1" REINFORCING PLATES PARALLEL TO EXISTING WEB
- PERFORMED FINITE ELEMENT ANALYSIS OF REINFORCED CONNECTION
- REPLACED APPROXIMATE MANUAL CALCULATION OF CONNECTION STRENGTH WITH ACCURATE COMPUTER ANALYSIS
- INCREASED CODE ALLOWABLE STRENGTH OF CONNECTION TO BE NEAR THAT OF COLUMN AND PIN CONNECTION AT BASE OF COLUMN

VENT HEADER SUPPORT COLUMN CONNECTION

● PURPOSE

- INCREASE CONNECTION CAPACITY TO BE NEAR THAT OF COLUMN IN TENSION
- CONNECTION CAPACITY 74 KIPS
- PIPE COL. CAPACITY 151 KIPS

● LOAD BASIS

- PLANT UNIQUE ANALYSIS REPORT
(SHORT TERM PROGRAM)
- POOL SWELL IMPACTING VENT HEADER
MAX. NET TENSION = 131 KIPS




Figure 3.3-1

VENT HEADER SUPPORTS




Figure 4.0-1
VENT HEADER COLUMN MODIFICATION

CODE ALLOWABLE CAPACITY

<u>ELEMENT</u>	<u>STRESS</u>	<u>UNREINF.</u>	<u>REINF.</u>
COLLAR	SHEAR	88 ^K	220 ^K
UPPER PIN	SHEAR	143 ^K	911 ^K
	BEARING	74 ^K	141 ^K
	BENDING	140 ^K	926 ^K
PIN PLATE	TENSION	134 ^K	134 ^K
	SHEAR	132 ^K	132 ^K
	WELD SHEAR	223 ^K	223 ^K
PIPE COL.	TENSION	151 ^K	151 ^K
LOWER PIN	SHEAR	143 ^K	548 ^K
	BEARING	111 ^K	141 ^K
	BENDING	117 ^K	449 ^K
RING WEB	SHEAR	138 ^K	138 ^K

SYSTEM

UNREINFORCED CAPACITY = 74^KREINFORCED CAPACITY = 132^K

ULTIMATE CAPACITY

<u>ELEMENT</u>	<u>STRESS</u>	<u>UNREINF.</u>	<u>REINF.</u>
COLLAR	SHEAR	276 ^K	690 ^K
UPPER PIN	SHEAR	606 ^K	1885 ^K
	BEARING	308 ^K	462 ^K
	BENDING	373 ^K	2469 ^K
PIN PLATE	TENSION	548 ^K	548 ^K
	SHEAR	413 ^K	413 ^K
	WELD SHEAR	589 ^K	589 ^K
PIPE COL.	TENSION	462 ^K	462 ^K
LOWER PIN	SHEAR	606 ^K	1134 ^K
	BEARING	462 ^K	462 ^K
	BENDING	313 ^K	1197 ^K
RING WEB	SHEAR	431 ^K	431 ^K

SYSTEM

UNREINFORCED CAPACITY = 276^KREINFORCED CAPACITY = 413^K

VENT HEADER SUPPORT CAPACITIES

	CODE ALLOWABLE	ULTIMATE	STRENGTH RATIO
PRIOR TO REINFORCEMENT	74K	276K	0.47
AFTER REINFORCEMENT	132K	413K	0.32

STP LOAD = 131 KIPS

DRYWELL/WETWELL DIFFERENTIAL PRESSURE REMOVAL

● NRC CRITERIA

- DETERMINE LOADS W/O ΔP USING
STP REPORT ADDENDUM 2
- INCREASE LOADS W/O ΔP BY 33%
- LIMITING STRENGTH RATIO = 0.50

TABLE 2.1-1
TORUS SUPPORT COLUMN MAXIMUM COMPRESSIVE LOADS
AT MINIMUM WATER LEVEL

1	2	3	4	5	6	7
COLUMN	POOLSWELL LOAD (ΔP) (KIPS) (1)	ADJUSTED POOLSWELL LOAD (KIPS) (2)	STEEL & WATER LOAD (KIPS) (1)	VERTICAL SEISMIC LOAD (KIPS) (1)	HORIZONTAL SEISMIC LOAD (KIPS) (1)	TOTAL LOAD (KIPS) (3)
INSIDE	493.3	795.3	147.6	8.8	4.7	956.4
OUTSIDE	655.9	1057.4	172.6	10.4	8.3	1248.7

NOTES:

(1) NSP-01-140, Table 6.1.1-1, minimum submergence, Reference 2

(2) "Acceptance Criteria for the Removal or Reduction of Drywell-Wetwell Differential Pressure Controls"

$$493.3 \times \left(\frac{1}{.825}\right) \times (1.33) = 795.3$$

$$655.9 \times \left(\frac{1}{.825}\right) \times (1.33) = 1057.4$$

(3) Summation of columns 3, 4, 5, and 6

TABLE 2.1-2

DOWNWARD LOADSULTIMATE CAPACITIES AND STRENGTH RATIOSAT MINIMUM WATER LEVEL

1		2	3	4
COMPONENT		LOAD (KIPS) (1)	STP ULTIMATE CAPACITY (KIPS)	ULTIMATE STRENGTH RATIO
INSIDE	SHELL CONNECTION	956.4	2820 (2)	.34
	COLUMN		3140 (3)	.30
	PIN CONNECTION		2960 (3)	.32
OUTSIDE	SHELL CONNECTION	1248.7	2820 (2)	.44
	COLUMN		3288 (3)	.38
	PIN CONNECTION		2960 (3)	.42

NOTES:

- (1) Adjusted no ΔP load for minimum submergence from Table 2.1-1
- (2) Capacities per NSP-01-176, Reference 4
- (3) Capacities per NSP-01-140, Reference 2

TABLE 2.1-3

STRESS INTENSITIES AND STRENGTH RATIOS
FOR RING AND SHELL AT MINIMUM WATER LEVEL

1	2	3	4	5	6	7	8	9
COMPONENT	MAXIMUM STRESS INTENSITY (KSI) (1)		ADJUSTED MAXIMUM STRESS INTENSITY (KSI) (2)		STP ULTIMATE CAPACITY (KSI)		ULTIMATE STRENGTH RATIO	
	P_L	$P_L + Q$	P_L	$P_L + Q$	P_L	$P_L + Q$	P_L	$P_L + Q$
RING	16.6	16.6	23.9	23.9	76.0	76.0	.31	.31
SHELL	21.6	24.0	32.2	36.2	76.0	76.0	.42	.48

NOTES:

- (1) Stress from NRP-01-140 for minimum submergence with Δp (1.0 psi), Reference 2.
- (2) Pool Swell loads without Δp increased by 1/3 and added to dead load plus seismic
- (3) P_L = Local primary membrane stresses
- (4) Q = Secondary stresses

Table 2.2-1
TORUS SUPPORT COLUMN MAXIMUM COMPRESSIVE LOADS
AT MAXIMUM WATER LEVEL

1	2	3	4	5	6	7
COLUMN	POOLSWELL LOAD (ΔP) (KIPS) (1)	ADJUSTED POOLSWELL LOAD (KIPS) (2)	STEEL & WATER LOAD (KIPS) (3)	VERTICAL SEISMIC LOAD (KIPS) (3)	HORIZONTAL SEISMIC LOAD (KIPS) (3)	TOTAL LOAD (KIPS) (4)
INSIDE	530.9	855.9	164.0	9.8	5.2	1034.9
OUTSIDE	705.9	1138.0	191.8	11.6	9.2	1350.6

NOTES:

- (1) NSP-01-168, Table 2, Maximum submergence, Reference 5
- (2) "Acceptance Criteria for the Removal or Reduction of Drywell-Wetwell Differential Pressure Controls"
- $$530.9 \times \left(\frac{1}{.825} \right) \times (1.33) = 855.9$$
- $$705.9 \times \left(\frac{1}{.825} \right) \times (1.33) = 1138.0$$
- (3) Table 2, NSP-01-168
- (4) Summation of Columns 3, 4, 5, and 6

TABLE 2.2-2

DOWNWARD LOADSULTIMATE CAPACITIES AND STRENGTH RATIOSAT MAXIMUM WATER LEVEL

1		2	3	4
COMPONENT		LOAD (KIPS) (1)	STP ULTIMATE CAPACITY (KIPS)	ULTIMATE STRENGTH RATIO
INSIDE	SHELL CONNECTION	1034.9	2820 (2)	.37
	COLUMN		3140 (3)	.33
	PIN CONNECTION		2960 (3)	.35
OUTSIDE	SHELL CONNECTION	1350.6	2820 (2)	.48
	COLUMN		3288 (3)	.41
	PIN CONNECTION		2960 (3)	.46

NOTES:

- (1) Adjusted no ΔP load for maximum submergence from Table 2.2-1
- (2) Capacities per NSP-01-176, Reference 4
- (3) Capacities per NSP-01-140, Reference 2

STRUCTURAL CAPACITY SUMMARY

- TORUS SUPPORT COLUMN CONNECTIONS
HAVE BEEN REINFORCED

- VENT HEADER SUPPORT COLUMN
CONNECTION REINFORCEMENT IS
PLANNED

- NRC CRITERIA FOR ΔP REMOVAL DURING
SRV DISCHARGE TEST IS SATISFIED

TABLE 2.2-3

STRESS INTENSITIES AND STRENGTH RATIOSFOR RING AND SHELL AT MAXIMUM WATER LEVEL

1	2	3	4	5	6	7	8	9
COMPONENT	MAXIMUM STRESS INTENSITY (KSI) (1)		ADJUSTED MAXIMUM STRESS INTENSITY (KSI) (2)		STP ULTIMATE CAPACITY (KSI)		ULTIMATE STRENGTH RATIO	
	P_L	$P_L + Q$	P_L	$P_L + Q$	P_L	$P_L + Q$	P_L	$P_L + Q$
RING	16.6	16.6	25.4	25.4	76.0	76.0	.33	.33
SHELL	21.6	24.0	34.4	38.7	76.0	76.0	.45	MEETS CODE

NOTES:

- (1) Stress from NSP-01-140 for minimum submergence with Δp (1.0 psi), Reference 2.
- (2) Pool swell loa's with Δp increased by 1/3 and added to dead load plus seismic
- (3) P_L = Local primary membrane stresses
- (4) Q = Secondary stresses

TABLE 2.2-3A

STRESS INTENSITIES AND STRENGTH RATIOS
FOR RING AND SHELL AT MAXIMUM WATER LEVEL

1	2	3	4	5	6	7	8	9
COMPONENT	MAXIMUM STRESS INTENSITY WITHOUT ΔP (ksi) (1)		CODE ALLOWABLE STRESS INTENSITY (ksi) (2)		STP ULTIMATE CAPACITY (ksi)		STRENGTH RATIO ULTIMATE\CODE	
	P_L	P_L+Q	P_L	P_L+Q	P_L	P_L+Q	P_L	P_L+Q
RING	20.5	20.5	19.3	57.8	76.0	76.0	1.06 .27	.35 MEETS CODE
SHELL	26.9	30.1	28.95	57.8	76.0	76.0	.93 MEETS CODE	.52 MEETS CODE

NOTES:

- (1) Pool swell loads without Δp added to dead load plus seismic
- (2) NSP-01-140
- (3) P_L = Local primary membrane stresses
- (4) Q = Secondary stresses

TABLE 2.2-2

DOWNWARD LOADSULTIMATE CAPACITIES AND STRENGTH RATIOSAT MAXIMUM WATER LEVEL

1		2	3	4	5	6
COMPONENT		LOAD (KIPS) (1)	CODE ALLOWABLE LOAD (KIPS)	ULTIMATE CAPACITY (KIPS)	CODE ALLOWABLE RATIO	ULTIMATE CAPACITY RATIO
INSIDE	SHELL CONNECTION	1034.9	940 (2)	2820 (2)	1.10	.37
	COLUMN		1117 (3)	3121 (3)	.93	MEETS CODE
	PIN CONNECTION		993 (3)	2960 (3)	1.04	.35
OUTSIDE	SHELL CONNECTION	1350.6	940 (2)	2820 (2)	1.44	.48
	COLUMN		1166 (3)	3172 (3)	1.16	.43
	PIN CONNECTION		993 (3)	2960 (3)	1.36	.46

NOTES:

- (1) Adjusted no ΔP load for maximum submergence from Table 2.2-1
- (2) Capacities per NSP-01-176, Reference 4
- (3) Capacities per NPS-01-140, Reference 2

TABLE 2.2-3

STRESS INTENSITIES AND STRENGTH RATIOS
FOR RING AND SHELL AT MAXIMUM WATER LEVEL

1	2	3	4	5	6	7	8	9
COMPONENT	ADJUSTED MAXIMUM STRESS INTENSITY (ksi) (1)		CODE ALLOWABLE STRESS INTENSITY (ksi) (2)		STP ULTIMATE CAPACITY (ksi)		STRENGTH RATIO ULTIMATE/ CODE	
	P_L	$P_L + Q$	P_L	$P_L + Q$	P_L	$P_L + Q$	P_L	$P_L + Q$
RING	25.4	25.4	19.3	57.8	76.0	76.0	1.32 .33	.44 MEETS CODE
SHELL	34.4	38.7	28.95	57.8	76.0	76.0	1.19 .45	.67 MEETS CODE

NOTES:

- (1) Pool swell loads without ΔP increased by 1/3 and added to dead load plus seismic
- (2) NSP-01-140
- (3) P_L = Local primary membrane stresses
- (4) Q = Secondary stresses

ENCLOSURE 2

 NSP-11-019
 Revision 1

TABLE 2.2-1A

TORUS SUPPORT COLUMN MAXIMUM COMPRESSIVE LOADS
AT MAXIMUM WATER LEVEL

1	2	3	4	5	6	7
COLUMN	POOLSWELL LOAD ΔP (kips) (1)	POOLSWELL LOAD WITHOUT ΔP (kips) (2)	STEEL & WATER LOAD (kips) (3)	VERTICAL SEISMIC LOAD (kips) (3)	HORIZONTAL SEISMIC LOAD (kips) (3)	Notes
INSIDE	530.9	643.5	164.0	9.8	5.2	822.3
OUTSIDE	705.9	855.6	191.8	11.6	9.2	1068.2

NOTES:

- (1) NSP-01-168, Table 2, Maximum submergence, Reference 5
 (2) Determination of Poolswell Load without Drywell-Wetwell differential pressure

$$530.9 \times \left(\frac{1}{.825}\right) = 643.5$$

$$705.9 \times \left(\frac{1}{.825}\right) = 855.6$$

- (3) Table 2, NSP-01-168
 (4) Summation of Columns 3, 4, 5, and 6

TABLE 2.2-2A

DOWNWARD LOADSULTIMATE CAPACITIES AND STRENGTH RATIOSAT MAXIMUM WATER LEVEL

1		2	3	4	5	6
COMPONENT		LOAD (KIPS) (1)	CODE ALLOWABLE LOAD (KIPS)	ULTIMATE CAPACITY (KIPS)	CODE ALLOWABLE RATIO	ULTIMATE CAPACITY RATIO
INSIDE	SHELL CONNECTION	822.5	940 (2)	2820 (2)	.88	MEETS CODE
	COLUMN		1120 (3)	3131 (3)	.73	MEETS CODE
	PIN CONNECTION		993 (3)	2960 (3)	.83	MEETS CODE
OUTSIDE	SHELL CONNECTION	1068.2	940 (2)	2820 (2)	1.14	.38
	COLUMN		1178 (3)	3236 (3)	.91	MEETS CODE
	PIN CONNECTION		993 (3)	2960 (3)	1.08	.36

NOTES:

- (1) Poolswell Load without ΔP for maximum submergence from Table 2.2-1A
- (2) Capacities per NSP-01-176, Reference 4
- (3) Capacities per NSP-01-140, Reference 2

50-263

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:

Mr. Victor Stello

FROM:

 Northern States Power Company
 Minneapolis, Minnesota
 L. O. Mayer

DATE OF DOCUMENT

8/29/77

DATE RECEIVED

8/31/77

☒ LETTER

☒ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL
☐ COPY

☒ UNCLASSIFIED

3 SIGNED

DESCRIPTION

ENCLOSURE

 Consists of response to NRC request for
 information concerning the Mark I
 Containment.....notorized 8/29/77.....

ACKNOWLEDGED

(2-P)

(1/4")

 PLANT NAME: Monticello
 RJL 8/31/77

DO NOT REMOVE

SAFETY

FOR ACTION/INFORMATION

ENVIRONMENTAL

ASSIGNED AD:

ASSIGNED AD:

V. MOORE (LTR)

BRANCH CHIEF: (7)

DAVIS

BRANCH CHIEF:

PROJECT MANAGER:

PROJECT MANAGER:

LICENSING ASSISTANT:

LICENSING ASSISTANT:

B. HARLESS

INTERNAL DISTRIBUTION

REG FILES	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
NRC PDR	HEINEMAN	TEDESCO	ENVIRON ANALYSIS
T & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
OFELD LTR		LAINAS	CRITCHFIELD
GOSSICK & STAFF LTR	ENGINEERING	IPPOLITO	
HANAUER	ENLIT	F. ROSA	ENVIRO TECH.
MYPC	BOSNAK		ERNST
CASE LTR	SINELL	OPERATING REACTORS	BALLARD
BOYD LTR	FABLICKI	STELLO	YOUNGBLOOD
DE YOUNG LTR	GILBERT	EISENHUT	
PROJECT MANAGEMENT	REACTION SAFETY	SHAO	SITE TECH.
SKOVHOLT	ROSS	BAER	
P. COLLINS	NOVAK	BUTLER (2)	GAMMILL (2)
HOUSTON	ROSZTOGYI	GRIMES	
MELTZ	CHECK		SITE ANALYSIS
HEITEMES			VOLLMER
SK	AT&I		BUNCH
	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: MINNEAPOLIS MN.

TIC

NSIC

NAT LAB

REG IV (J. HANCHETT)

16 CYS ACRS SENT CATEGORY B

772430291