

EXHIBIT B

LICENSE AMENDMENT REQUEST DATED JUNE 9, 1975

Exhibit B, attached, consists of newly prepared page 76 for the Appendix A Technical Specifications which incorporates the proposed changes.

3.0 LIMITED CONDITIONS FOR OPERATION

2. Reactivity margin - stuck control rods.

Control rod drives which cannot be moved with control rod drive pressure shall be considered inoperable. The directional control valves for inoperable control rods shall be disarmed electrically and the rods shall be in such positions that Specification 3.3.A.1 is met. If more than six non-fully inserted rods are inoperable during power operation the reactor shall be placed in a shut-down condition.

B. Control Rod Withdrawal

1. Each control rod shall be coupled to its drive or completely inserted and the directional control valves disarmed electrically. This requirement does not apply when removing a control rod drive for inspection as long as the reactor is in the refueling mode.

4.0 SURVEILLANCE REQUIREMENTS

2. Reactivity margin - stuck control rods.

Each fully withdrawn operable control rod shall be exercised one notch at least once each week. In the event power operation is continuing with two or more non-fully inserted rods electrically disarmed, this test shall be performed at least once each day.

B. Control Rod Withdrawal

1. The coupling integrity shall be verified for each withdrawn control rod as follows:
 - (a) when the rod is fully withdrawn the first time subsequent to each refueling outage, observe that the drive does not go to the overtravel position; and

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 6132

FILE: _____

FROM: Northern States Pwr Minneapolis, Mn. L O Mayer		DATE OF DOC 6-9-75	DATE REC'D 6-11-75	LTR XX	TWX	RPT	OTHER
TO: Mr. A Giambusso		ORIG 3 signed	CC	OTHER	SENT NRC PDR <u>XXXX</u> SENT LOCAL PDR <u>XXXX</u>		
CLASS	UNCLASS XXXX	PROP INFO	INPUT	NO CYS REC'D 40	DOCKET NO: 50-263		

DE NOTION: Ltr notarized 6-9-75, request for spec change of the provisional operating license trans the following...

ENCLOSURES: Propose change that would eliminate the requirement for exercising partially withdrawn control rods weekly...

40 copies encl rec'd

PLANT NAME: Monticello

MOVE

FOR ACTION/INFORMATION w/ 6-11-75

BUTLER (L) W/ Copies	SCHWENDER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	STERS W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNG BLOOD (E) W/ Copies	_____

INTERNAL DISTRIBUTION

REG FILE	TECH REVIEW	DENTON	LIC ASST	A/T IND
NRC PDR	SCHROEDER	GRIMES	R. DIGGS (L)	BRAITHMAN
OGC, ROOM P 906A	MAGGLEY	GAMMILL	H. GEARIN (L)	SALTZMAN
GOSSICK STAFF	KNIGHT	KASTNER	E. COULBOURNE (L)	MFLT
CASE	PAWLICKI	BALLARD	P. KREUTZER (E)	PLANS
GIAMBUSO	SHAO	SPANGLER	J. LEE (L)	MCDONALD
BOYD	STELLO		M. MAIGRET (L)	CHAPMAN
MOORE (L)	HOUSTON	ENVIRO	S. REED (E)	DUBE (L)
DEYOUNG (L)	NOVAK	MULLER	M. SERVICE (L)	B. COUPE
SKOVHOLT (L)	ROSS	DICKER	S. SHEPPARD (L)	PETERSON
GOLLER (L) (LH)	IPPOLITO	KNIGHTON	M. SLATER (E)	HARTFIELD (L)
P. COLLINS	TEDESCO	YOUNGBLOOD	H. SMITH (L)	KLECKER
DENISE	LONG	REGAN	S. TEETS (L)	EISENHUT
DEC ORP (L)	LAINAS	PROJECT LDR	G. WILLIAMS (E)	WIGGINS
FILE & REGION (2)	BENAGAYA	HARLESS	V. WILSON (L)	E. HUGHES
MPC	VOLLMER		R. INGRAM (L)	
			M. DUNCAN	

EXTERNAL DISTRIBUTION

1 - LOCAL PDR, Minneapolis, Mn	1 - NATIONAL LABS	1 - PDR SAR/LA/NY
1 - TIC (ALBANY) (LH) (LH)	1 - W. PERNINGTON, Rm E 201 CT	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - CONSULTANTS	1 - G. ULRIKSON, OHNL
1 - ASD	NEWMARK/BLUM/AGBARIAN	
1 - Newton Anderson		
1 - ACHT		