



TU ELECTRIC

Log # TXX-91084  
File # 916 (3/4.3)  
Ref. # 10CFR50.90  
10CFR50.92

William J. Cahill, Jr.  
Executive Vice President

April 26, 1991

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES), UNIT 1  
DOCKET NO. 50-445  
OUTAGE TIMES AND SURVEILLANCE TEST INTERVALS FOR  
VARIOUS ENGINEERED SAFETY AND REACTOR TRIP FUNCTIONS  
LICENSING AMENDMENT REQUEST 91-003

Gentlemen:

Pursuant to 10CFR50.90, Texas Utilities Electric Company (TU Electric) hereby requests an amendment to its Facility Operating License No. NPF-87 by incorporating the enclosed change to Technical Specification Tables 3.3-1, 3.3-2, 4.3-2, and BASES 3/4.3.1 and 3/4.3.2 for Comanche Peak Steam Electric Station.

The enclosed License Amendment Request (LAR) proposes to modify the Comanche Peak Steam Electric Station Unit 1 Technical Specifications by changing the Allowed Outage Times (AOT) and the Surveillance Test Intervals (STI) for Analog Channels shared by both the Reactor Trip System (RTS) and the Engineered Safety Features Actuation System (ESFAS).

The proposed change will result in less frequent testing which will result in fewer inadvertent reactor trips and fewer actuations of ESFAS components.


The change proposed in this LAR is not required to address an immediate safety concern. TU Electric desires to implement the requested change as soon as possible and therefore, requests timely review and approval of this LAR by the NRC. TU Electric requests that the revised Technical Specifications be made effective seven days after approval of the license amendment by the NRC.

DO29

TX-91084  
Page 2 of 2

In accordance with 10CFR50.91(b), TU Electric is providing the State of Texas a copy of this proposed amendment.

Sincerely,



William J. Cahill, Jr.

JDR/grp

- Attachment
1. Affidavit
  2. Proposed change and Significant Hazards Consideration Evaluation (10CFR50.92)
  3. Proposed replacement pages.


c - Mr. R. D. Martin, Region IV  
Resident Inspectors, CPSES (3)  
Mr. J. W. Clifford, NRR  
D. K. Lacker  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, Texas 78704

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
Texas Utilities Electric Company ) Docket No. 50-445  
(Comanche Peak Steam Electric )  
Station, Unit 1) )

AFFIDAVIT


William J. Cahill, Jr. being duly sworn, hereby deposes and says that he is Executive Vice President, Nuclear of TU Electric, that he is duly authorized to sign and file with the Nuclear Regulatory Commission this License Amendment Request; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.

  
William J. Cahill, Jr.  
Executive Vice President, Nuclear

STATE OF TEXAS )  
COUNTY OF SOMERVELL )

Subscribed and sworn to before me, a Notary Public, on this 26th day of  
April, 1991.



  
Notary Public