



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4040

John L. Skolds
Vice President
Nuclear Operations

MAY 24 1991
91 MAY 29 AM 11:46

Mr. S. D. Ebnetter
Regional Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 2900
131 Marietta Street, NW
Atlanta, GA 30323

Dear Mr. Ebnetter:

SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT (SPR 910003) (ONO 910027)

A requirement of Station Administrative Procedure (SAP) 131A, "Fire Service Equipment/System Operability Requirements," is that a Special Report be submitted if a fire pump is inoperable in excess of seven days.

On April 29, 1991, the Electric Driven Fire Pump (XPP-134A) was removed from service as a result of surveillance testing which indicated pump wear or fouling to the extent that the minimum flow requirements were being approached. A new pump was installed, tested, and declared operable May 9, 1991. The total time inoperable was 10.5 days.

Should there be any questions, please call at your convenience.

Very truly yours,

John L. Skolds

RJB:JLS:lcd

c: O. W. Dixon Jr.
R. R. Mahan
R. J. White
General Managers
G. F. Wunder
C. A. Price
NRC Resident Inspector
J. B. Knotts Jr.

Marsh & McLennan
Document Control Desk
INPO Records Center
ANI Library
NSRC
RTS (ONO 910027)
File (818.05 & 813.08)

NUCLEAR EXCELLENCE - A SUMMER TRADITION!

9106100314 910524
PDR ADOCK 05000395
S PDR

110
IE 22