

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
Omaha Public Power District)	Docket No. 50-285
(Fort Calhoun Station)	
Unit No. 1))	

APPLICATION FOR AMENDMENT
OF
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission ("the Commission"), Omaha Public Power District, holder of Facility Operating License No. DPR-40, herewith requests that the Technical Specifications set forth in Appendix A to that License be amended to delete redundant surveillance test requirements contained in Specifications 3.2 Table 3-5, 3.6, and to revise the basis of Specification 2.4.

The proposed changes in Technical Specifications are provided in Attachment A to this Application. A Discussion, Justification and No Significant Hazards Consideration Analysis, which demonstrates that the proposed changes do not involve significant hazards considerations, is appended in Attachment B. The proposed changes in specifications would not authorize any change in the types or any increase in the amounts of effluents that will be released, or a change in the authorized power level of the facility.

WHEREFORE, Applicant respectfully requests that Specifications 3.2 Table 3-5, 3.6, and the basis of Specification 2.4 of Appendix A to Facility Operating License No. DPR-40 be amended in the form attached hereto as Attachment A.


A copy of this Application, including its attachments, has been submitted to the Director - Nebraska State Division of Radiological Health, as required by 10 CFR 50.91.

OMAHA PUBLIC POWER DISTRICT

By *J. S. Palt*
Division Manager - Nuclear Operations

Subscribed and sworn to before me this 7th day of October, 1994.

Theresa Petersen
Notary Public



U.S. Nuclear Regulatory Commission
LIC-94-0196

ATTACHMENT A