

CONTROL BLOCK:

--	--	--	--	--	--	--

 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	2	3	7	7	1	0	1	8	7	8	3	1	1	1	2	7	8	9
60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80			

0 2 | During normal operation, LPCI suction valve MO-2-1501-5C failed to close while per-

0 3 | forming DOS 1500-1 LPCI system valve operability test. The valve was hand cranked

0 4 | off the back-seat and cycled three times satisfactorily. Since the valve is open

0 5 | during LPCI operation and the LPCI pump operability was not impaired, safety sig-

0 6 | nificance was minimal. This is the first occurrence of this type of failure.

0 7 |

0 8 |

8 9

SYSTEM CODE 09		CAUSE CODE SF		CAUSE SUBCODE E		COMPONENT CODE V A L V E X				COMP. SUBCODE E		VALVE SUBCODE D					
EVENT YEAR 78		SEQUENTIAL REPORT NO. 058		OCCURRENCE CODE 03		REPORT TYPE L		REVISION NO. 0									
ACTION TAKEN E		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0000		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER C665	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Valve stem was not adequately lubricated. After lubricating stem, the valve was

1 1 successfully cycled three times. The breaker contactors were cleaned and checked and

1 2 the torque switch settings were verified before the valve was cycled.

1 3 Valve lubrication program had the valve scheduled for lubrication in October, but

1 4 valve failed before lubrication was accomplished. Lubrication interval shortened (OVER)

FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION									
E (28)										0 9 5 (29) NA										B (31)										Surveillance testing (32)																			
ACTIVITY CONTENT										RELEASED OF RELEASE										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																			
Z (33)										Z (34) NA										NA										(35)																			
PERSONNEL EXPOSURES										NUMBER										TYPE										DESCRIPTION																			
0 0 0 (37)										Z (38)										NA										7811210/81 S																			
PERSONNEL INJURIES										NUMBER										DESCRIPTION																													
0 0 0 (40)										NA																																							
LOSS OF OR DAMAGE TO FACILITY										TYPE										DESCRIPTION																													
Z (42)										NA																																							
PUBLICITY										ISSUED										DESCRIPTION										NRC USE ONLY																			
NA (44)										NA																																							

NAME OF PREPARER John Achterberg

PHONE: 265

to 6 mos.