

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

USNRC REGION I
ATLANTA, GEORGIA
82 AUG 16 P 4: 10



Vogtle Project

August 11, 1982

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG10
Log: GN-188

Reference: 50-424/82-13
50-425/82-13

Attention: R. C. Lewis

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the violations discussed in your inspection report 50-424/82-13 and 50-425/82-13.

We concur with the finding identified concerning failure to take effective corrective action. The reason for the violation was ineffective controls because we were in the process of implementing a new housekeeping procedure.

Contractor craftsmen have been assigned to perform a daily inspection of the chemical and volume control system (CVCS) charging pumps for compliance to storage requirements. In addition, to better control access to the rooms containing these pumps, the Unit 2 rooms will be locked until piping installation starts and the Unit 1 rooms will be locked after work in this area is complete.

The new housekeeping procedure has been fully implemented and requires Quality Control inspectors to inspect storage areas at least monthly to verify:

- 1) area cleanliness and access control,
- 2) condition of coatings and preservatives,
- 3) protective covers and seals maintained,
- 4) identification and markings, and
- 5) inspection for physical damage.


In addition to the above, weekly and spot/random walk-throughs will help avoid future violations in this area.

8209160214 820820
PDR ADOCK 05000424
G FDR

Full compliance was achieved on June 1, 1982.

This response contains no proprietary information and may be placed
in the NRC Public Document Room upon receipt.

Yours truly,



D. O. Foster
Project General Manager

DOF/CWH/tlp

xc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Stello, Jr., Director
Office of Inspection and Enforcement
Washington, D.C. 20555

R. J. Kelly
R. E. Conway
G. F. Head
J. T. Beckham, Jr.
J. H. Boykin
D. E. Dutton
R. H. Pinson
D. L. McCrary
R. A. Thomas
J. A. Bailey
O. Batum
H. H. Gregory, III
E. D. Groover
L. T. Gucwa
M. Malcom
C. R. Miles, Jr.
M. Manry
P. D. Rice
R. W. Staffa
J. L. Vota
W. F. Sanders