

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)01 P A S E S 1 2 0 0 0 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 3 8 7 7 0 8 2 0 8 2 8 0 9 0 3 8 2 9
7 8 60 61 DOCKET NUMBER 98 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During preoperational testing, the Control Room Emergency Outside Air Supply

03 System (CREOASS) did not automatically start on an isolation signal during per-

04 formance of a surveillance test. This event is reportable per T.S. 6.9.1.8.e.

05 There were no adverse consequences as a result of the event in that it

06 occurred during a surveillance test.

07

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
A A 11 A 12 X 13 X X X X X X X 14 X 15 Z 16

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 2 0 0 5 0 1 T 1

18 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER (26)
X 18 H 19 Z 20 Z 21 0 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Unauthorized personnel had apparently placed the flow controller in the

11 CASCADE mode rather than the LOCAL mode thus preventing automatic operation.

12 Plant personnel will be cautioned on changing switches and setting of equip-

13 ment controls. Completion of this reinstruction will occur by 9/30/82.

14

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
B 28 0 0 0 29 NA B 31 Surveillance Testing

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 NA

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 NA

20 PUBLICITY ISSUED DESCRIPTION (45)
N 44 NA

21 NRC USE ONLY

NAME OF PREPARER D. G. Mitchell

PHONE: 717-542-2181-524