

[illegible]

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	-	0	3	2	5	7	0	8	1	2	8	2	8	0	9	0	9	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing a review of surveillance procedures to assure technical adequacy, it

0 3 | was determined that plant procedures did not provide for a required once per 18 month

0 4 | operability and functional test of AOG Building miscellaneous fire doors, hatches and

0 5 | seals. This event did not affect the health and safety of the public.

0 6 | Technical Specifications 4.7.8, 6.9.1.9c

0 7 |

0 8 |

09		SYSTEM CODE A B		11	CAUSE CODE D		12	CAUSE SUBCODE Z Z Z Z Z Z						13	COMP. SUBCODE Z						14	VALVE SUBCODE Z		15	16
7	8	9	10		11	12	13	14	15	16	17	18	19	20											
17		LER/RO REPORT NUMBER		EVENT YEAR 8 2		21	22	SEQUENTIAL REPORT NO. 0 9 8		24	25	26	OCCURRENCE CODE 0 3		28	29	REPORT TYPE L		30	REVISION NO. 0		32			
ACTION TAKEN X		FUTURE ACTION G		18	EFFECT ON PLANT Z		19	SHUTDOWN METHOD Z		20	HOURS 0 0 0 0		22	ATTACHMENT SUBMITTED N		23	NPRD-4 FORM SUB. N		24	PRIME COMP. SUPPLIER Z		25	COMPONENT MANUFACTURER Z 9 9 9		26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This procedural inadequacy occurred due to personnel oversight during development of

1 1 the applicable surveillance procedure, PT-35.18.3. A temporary revision was made to

1 2 the PT and the required components were satisfactorily tested on 8-13-82. Prior to

1 3 start-up of both units, a permanent revision to the PT will be made to reflect the

1 4 subject surveillance.

1 5 G 28 0 0 0 29 NA C 31 Procedure Technical Review

ACTIVITY RELEASED

CONTENT OF RELEASE

AMOUNT OF ACTIVITY

LOCATION OF RELEASE

7 8 9 10 11 44

1 6 Z 33 34 NA NA

PERSONNEL EXPOSURES									
NUMBER				TYPE		DESCRIPTION			
1	7	C	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	0	0	40
		NA	
8209160313			

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
1 9 Z (42) PDR ADOCK 05000325 PDR

2		0	N	44	NA												NRC USE ONLY												
7	8	9	10	11	68												69												80

NAME OF PREPARER M. J. PASTVA, JR.

PHONE: 919-457-9521