

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	---

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0	1	L	6	0	5	0	-	0	3	2	4	7	0	8	1	0	8	2	8	0	9	0	9	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During shutdown operation an attempt to operate the A loop core spray subsystem

0 3 room cooler determined that the service water discharge valve 2-SW-V128 would not

0 4 operate properly. Its travel was found to be restricted in both the open and closed

0 5 position. The remaining core spray loop and both RHR loops were operable at the time.

0 6 This event did not affect the health or safety of the public.

0 7

0 8 Technical Specification 3.5.3.1, 6.9.1.9b

0	9	S	F	11	E	12	X	13	V	A	L	V	O	P	14	D	15	Z	16
---	---	---	---	----	---	----	---	----	---	---	---	---	---	---	----	---	----	---	----

7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 21 EVENT YEAR 22 8 2 23 24 1 0 2 25 26 27 28 0 3 29 30 L 31 32 0 33 ACTION TAKEN 34 X 35 FUTURE ACTION 36 Z 37 EFFECT ON PLANT 38 Z 39 SHUTDOWN METHOD 40 0 0 0 0 41 HOURS 42 N 43 ATTACHMENT SUBMITTED 44 N 45 NPRD-4 FORM SUB. 46 N 47 PRIME COMP. SUPPLIER 48 A 49 3 2 2 50 COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Valve cylinder operation was restricted by gummed up old grease. It is believed

1 1 that the grease attained this condition due to moisture from the air lines. The

1 2 operator was cleaned, rebuilt, and returned to service. A plant modification to

1 3 install better air dryers on Unit No. 2 has just been completed and this modification

1 4 will be installed on Unit No. 1 during its refueling outage.

1	5	G	28	0	0	0	29	NA	30	B	31	Operability Testing	32
---	---	---	----	---	---	---	----	----	----	---	----	---------------------	----

7 8 9 10 11 12 13 44 45 46 80
1 6 Z 33 Z 34 35 NA 36 LOCATION OF RELEASE 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 7 0 0 0 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 8 0 0 0 40 41 42 43 44 45 46 47 48 49 50
1 9 Z 42 43 44 45 46 47 48 49 50
2 0 N 44 45 46 47 48 49 50
PDR ADOCK 05000324 PDR
S
NRC USE ONLY
7-026

NAME OF PREPARER R. M. Poulk, Jr.

PHONE 919-457-9521