

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 0 8 0 9 8 2 8 0 9 0 8 8 2 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing a review of plant Fire Protection System surveillance procedures to
0 3 assure technical adequacy, it was discovered that procedures did not provide for
0 4 a required once per 18 month operability surveillance of three fire hose stations
0 5 in the Control Building and one fire hose station in the diesel generator tank area.
0 6 All other plant fire hose stations are covered in plant procedures. This event
0 7 did not affect the health and safety of the public.
0 8 Technical Specifications 4.7.7.4b, 6.9.1.9c
7 8 9 80

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
A B 11 A 12 X 13 Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER 8 2 21 22
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 G 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 Z 25 Z 9 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This procedural inadequacy occurred due to personnel oversight during development of
1 1 the applicable surveillance procedure. A temporary revision was made to the applicable
1 2 fire hose rack surveillance, PT-35.11.2, and the test was satisfactorily performed
1 3 on August 12, 1982. A permanent revision to PT-35.11.2, reflecting the required
1 4 surveillance of the subject fire hose station, is in progress.
7 8 9 80

1 5 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
G 28 0 0 0 29 NA C 31 Procedure Technical Review
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
0 0 0 37 Z 38 NA
7 8 9 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER DESCRIPTION
0 0 0 40 NA
7 8 9 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
Z 42
7 8 9 10 80

2 0 PUBLICITY ISSUED DESCRIPTION
N 44 NA
7 8 9 10 80

8209160467 820908
PDR ADOCK 05000325
S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE 919-457-9521