

CONTROL BLOCK:										PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION																			
F L S L S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 LICENSEE CODE LICENSE NUMBER LICENSE TYPE JO CAT																													
REPORT SOURCE L 5 0 5 0 0 0 3 3 5 7 0 8 0 4 8 2 3 0 9 0 2 8 2 9 DOCKET NUMBER EVENT DATE REPORT DATE																													
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During normal full power operation, refueling water tank level transmitter LT-07-2B failed high. This transmitter provides an input to channel MB of the Recirculation Actuation Signal. The transmitter was calibrated and returned to service. It subsequently failed again five days later. After both occurrences, action was taken in accordance with T.S. 3.3.2.1.b. Previous LER's were 78-1, 79-35. The health and safety of the public was not affected. Redundant transmitters were operable.																													
SYSTEM CODE I B 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE T 15 VALVE SUBCODE Z 16 LER/RO REPORT NUMBER 17 8 2 0 3 4 0 3 L 0 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC FORM 58 PRIME CORP. SUPPLIER COMPONENT MANUFACTURER B 13 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 F 1 1 2 0 25																													
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The cause of the level transmitter was apparently leakage past the diaphragm. The transmitter was completely dismantled and reassembled, and subsequently tested satisfactorily.																													
FACILITY STATUS E 28 0 9 9 29 NA ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43 NA PUBLICITY ISSUED DESCRIPTION 45 NA NRC USE ONLY										METHOD OF DISCOVERY (32) Operator Observation DISCOVERY DESCRIPTION (32) LOCATION OF RELEASE (36) NRC USE ONLY																			
NAME OF PREPARER P. L. Pace PHONE (304) 552-3654																													