

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

USNRC REGION 2
ATLANTA, GEORGIA
82 AUG 13 P 1: 18



Vogtle Project

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

August 11, 1982

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG10
Log: GN-189

Reference: 50-424/82-16
50-425/82-16

Attention: H. C. Dance

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the violations discussed in your inspection report 50-424/82-16 and 50-425/82-16.

We concur with the finding identified concerning failure to perform periodic maintenance of equipment within the specified maintenance period. The reason for the violation was removal of the maintenance report cards from the active file in order to reformat and revise the card entries. These cards were held inactive through some of the scheduled maintenance intervals because of the amount of revisions required.

The appropriate maintenance cards for items 2-1604-Q5-PS1 and 2-1604-Q5-PS4 have been revised and returned to the active inspection and maintenance program. Desk top instructions have been prepared to ensure that we have more efficient revision control of changes within the inspection and maintenance program. A special quality control inspection was conducted to assess the current condition of this equipment. This inspection identified no adverse findings.


To avoid future violations in this area, we have stopped the practice of "wholesale" retrieval of maintenance report cards from the active program to make card revisions. Cards will be removed from the program on a limited basis and will be returned to the active file prior to any inspection and/or maintenance requirements due date.

Full compliance was achieved on August 6, 1982.

8209160597 820817
PDR ADOCK 05000424
Q PDR

This response contains no proprietary information and may be placed
in the NRC Public Document Room upon receipt.

Yours truly,



D. O. Foster
Project General Manager

CWH/DOF/tlp

xc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Stello, Jr., Director
Office of Inspection and Enforcement
Washington, D. C. 20555

R. J. Kelly
R. E. Conway
G. F. Head
J. T. Beckham, Jr.
J. H. Boykin
D. E. Dutton
R. H. Pinson
D. L. McCrary
R. A. Thomas
J. A. Bailey
O. Batum
H. H. Gregory, III
E. D. Groover
L. T. Gucwa
M. Malcom
C. R. Miles, Jr.
M. Manry
P. D. Rice
R. W. Staffa
J. L. Vota
W. F. Sanders