

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	S	C	N	E	E	3	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5							
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33							
LICENSEE CODE														LICENSE NUMBER										LICENSE TYPE						CAT		58	

0	1	L	0	5	0	0	0	2	8	7	0	8	0	4	8	2	0	9	1	0	8	2	9												
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33									
REPORT SOURCE														DOCKET NUMBER										EVENT DATE						REPORT DATE					

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a refueling inspection of Reactor Coolant Pump (RCP) closure studs on

0 3 August 4, 1982 at 1000, it was determined that five closure studs, two on 3A1

0 4 and three on 3A2, on Unit 3's RCPs had been degraded in size below the minimum

0 5 acceptable diameter of 3.250 inches. This was reportable per T.S. 6.6.2.1.a.(9).

0 6

0 7

0 8

0	9	C	B	E	D	X	X	X	X	X	X	Z	Z		
7	8	9	10	11	12	13	14	15	16	17	18	19	20		
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE	

  

1	7	8	2	0	0	9	0	1	T	0	
7	8	9	10	11	12	13	14	15	16	17	
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	

  

1	8	X	Z	Z	0	0	0	0	N	N	L	B	2	6	5		
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The closure studs degraded because of boric acid corrosion due to a closure

1 1 gasket leakage. The studs were replaced by a more corrosion resistant material.

1 2 The closure stud inspection procedure will be reviewed to determine if it needs

1 3 to be revised to specify the stud position to be measured.

1 4

1	5	H	0	0	0	NA	B	Refueling inspection	
7	8	9	10	11	12	13	14	15	
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	

  

1	6	Z	Z	NA	NA
7	8	9	10	11	12
ACTIVITY CONTENT RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	

  

1	7	0	0	0	Z	NA
7	8	9	10	11	12	
PERSONNEL EXPOSURES NUMBER		TYPE		DESCRIPTION		

  

1	8	0	0	0	NA
7	8	9	10	11	12
PERSONNEL INJURIES NUMBER		TYPE		DESCRIPTION	

  

1	9	Z	NA
7	8	9	10
LOSS OF OR DAMAGE TO FACILITY TYPE		DESCRIPTION	

  

2	0	N	NA
7	8	9	10
PUBLICATION ISSUED DESCRIPTION		NAME OF PREPARER	

8209210048 820910  
PDR ADOCK 05000287  
S PDR

NRC USE ONLY

PHONE: (704) 373-8270