



PUBLIC SERVICE COMPANY OF COLORADO

P. O. BOX 840 · DENVER, COLORADO 80201

5909 East 38th Avenue, Denver, Colorado 80207

OSCAR R. LEE
VICE PRESIDENT

September 10, 1982
Fort St. Vrain
Unit No. 1
P-82385
FSV-65

Mr. Darrel G. Eisenhut, Director
Division of Reactor Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: Control of Heavy Loads

Dear Mr. Eisenhut:

As a result of our multi-party telephone conversation of 9-8-82 between George Kuzmycz and others of NRC and John Reesy and others of PSC, this memo is to advise that PSC is in compliance with the intent of the five interim action items for the control of heavy loads as listed in your letter of December 22, 1980. In summary, the five items are as follows:

- Item 1 Define safe load paths.
- Item 2 Procedures should be developed to cover load handling operations.
- Item 3 Crane Operators should be trained.
- Item 4 The crane should be inspected, tested, and maintained in accordance with Chapter 2-2 of ANSI B30.2-1976.
- Item 5 Special attention should be given to procedures, inspections, repairs, and training for cranes and crane operators.

A033


8209210 190 P

P-82385
Page 2
September 10, 1982

These items are all addressed and contained in PSC's "Crane Operating Procedure Manual."

PSC will continue to operate it's cranes in accordance with the normal Crane Operating Procedures.

Very truly yours,



O. R. Lee, Vice President
Electric Production

ORL/RAG:pa

cc: G. Kuzmycz