U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

/0/1/ REPORT SOURCE /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/8/2/3/8/2/ (8) /0/9/1/6/8/2/ (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On August 23, 1982, with Unit No. 2 in Mode 3, Fire Door S71-18 between the "2H" /

/0/3/ / Emergency Diesel Generator and the Turbine Building would not latch and lock. /

/0/4/ / Since a fire watch was immediately posted the public health and safety were not /

/0/5/ / affected. This event is contrary to T.S. 3.7.15 and reportable pursuant to T.S. /

/0/6/ / 6.9.1.9.b. /

/0/7/ / /

/0/8/ / /

SYSTEM CODE — CAUSE CODE — CAUSE SUBCODE — COMPONENT CODE — COMP. SUBCODE — VALVE SUBCODE

/0/9/ /A/B/ (11) /E/ (12) /A/ (13) /X/X/X/X/X/X/ (14) /Z/ (15) /Z/ (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR — SEQUENTIAL REPORT NO. — OCCURRENCE CODE — REPORT TYPE — REVISION NO.

/8/2/ /-/ /0/5/4/ /\/ /0/3/ /L/ /-/ /0/

ACTION TAKEN — FUTURE ACTION — EFFECT ON PLANT — SHUTDOWN METHOD — HOURS — ATTACHMENT SUBMITTED — NPRD-4 FORM SUB. — PRIME COMP. SUPPLIER — COMPONENT MANUFACTURER

/E/ (18) /X/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /A/ (25) /C/1/7/5/ (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / Fire Door S71-18 would not latch and lock because the latch was out of adjustment/

/1/1/ / and sticking. The latch was adjusted and lubricated and the operability of the /

/1/2/ / door verified. Design modifications to the fire doors are being pursued. /

/1/3/ / /

/1/4/ / /

FACILITY STATUS — %POWER — OTHER STATUS (30) — METHOD OF DISCOVERY — DISCOVERY DESCRIPTION (32)

/1/5/ /G/ (28) /0/0/0/ (29) / NA / /A/ (31) / STA Observation /

ACTIVITY RELEASED — CONTENT OF RELEASE — AMOUNT OF ACTIVITY (35) — LOCATION OF RELEASE (36)

/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES

NUMBER — TYPE — DESCRIPTION (39)

/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES

NUMBER — DESCRIPTION (41)

/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE — DESCRIPTION

/1/9/ /Z/ (42) / NA /

PUBLICITY

ISSUED — DESCRIPTION (45) — NRC USE ONLY

/2/0/ /N/ (44) / NA / / / / / / / / / / / / /

NAME OF PREPARER W. R. CARTWRIGHT PHONE (703) 894-5151

8209300199 820916
PDR ADOCK 05000339
S PDR