



**Consumers
Power
Company**

James W Cook
*Vice President - Projects, Engineering
and Construction*

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0453

July 16, 1982

Mr J G Keppler, Regional Administrator
U S Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND PROJECT -
INSPECTION REPORT NO 50-329/82-08 (DETP) & 50-330/82-08 (DETP)
File: 0.4.2 Serial: 18355

Reference: NRC letter, W S Little to J W Cook, dated
June 16, 1982 (Transmittal of Inspection
Report 82-08)

The subject Inspection Report (82-08) provided the results of an inspection of the Preoperational Testing Program. This letter provides the status of actions taken on the three open items identified in the inspection report.

Open Item 330/82-08-01: Review of Recent Preoperational Test Problems

The summary of recent preoperational test problems encountered at other plants is currently being reviewed by our Technical Department staff. The review is scheduled to be complete by July 21, 1982. Any additional administrative controls, if required, will be implemented after the review is completed.

Open Item 330/82-08-02: Chapter 14 FSAR Change

We have reviewed Chapter 14 of the FSAR and compared it to the Testing Program Manual and recent licensing commitments. The required changes in Chapter 14 were submitted on June 7, 1982 for inclusion in the next revision to the FSAR. This completed our action on this open item.

8209300204 820716
PDR ADOCK 05000329
Q PDR

JUL 22 1982

1 E01

Page 2


Mr J G Keppler

File: 0.4.2 Serial: 18355

July 16, 1982

Open Item 330/82-08-03: Review of Comments on the Testing Program Manual

The inspector's comments on the wording and content of selected Testing Program Manual (TPM) Procedures have been reviewed. The appropriate revisions to the TPM Procedures are now being prepared to incorporate the necessary changes.

A handwritten signature in cursive script, reading "James W. Cook". The signature is written in dark ink and is positioned to the right of the typed text.

CC: RJCook, USNRC Resident Inspector