

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 125

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

September 30, 1982

RECEIVED
1982

1982 OCT -3 PM 12:31

SCE

REGIONAL

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 82-105
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Section 6.9.1.13b of Appendix A, Technical Specifications to Operating License NPF-10, for San Onofre Unit 2, this submittal provides the required 30-day written report and copy of Licensee Event Report (LER) for an occurrence involving the Auxiliary Feedwater (AFW) System.

Limiting Condition for Operation (LCO) 3.7.1.2 requires three independent steam generator auxiliary feedwater pumps and associated flow paths to be operable in Modes 1, 2 and 3. On August 31, 1982 at 1125 while in Mode 2, the motor-driven AFW pump 2P-504 was declared inoperable and LCO 3.7.1.2 Action Statement a was entered. The Action Statement requires the inoperable AFW Train to be returned to service within 72 hours or cooldown must be initiated.

Pump 2P-504 was taken out of service because of the discovery of a leaky threaded plug on the pump discharge casing. Corrective action included cleaning of the threads, applying graffoil and reinstalling the plug. The pump was returned to service on September 1, 1982, thus satisfying LCO 3.7.1.2.

8210130499 820930
PDR ADOCK 05000361
S PDR

IE-22
82-346


September 30, 1982

Measures taken successfully eliminated the leak and no additional corrective measures are required.

Public health and safety was not affected by this event since any one of the two remaining operable AFW Trains would have performed its intended decay heat removal function, if called upon to do so. LER 82-105 (attached) addresses this event.

If there are any questions, please contact me.

Sincerely,



Enclosure: LER 82-105

cc: A. E. Chaffee (USNRC Resident Inspector San Onofre, Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information & Program Control

Institute of Nuclear Power Operations