

LICENSEE EVENT REPORT

CONTROL BLOCK: ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5					
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57 CAT 58				

CON'T

REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 2 0 7 8 1 8 0 2 2 7 8 1 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Following maintenance on primary containment atmospheric oxygen analyzer, 8/1/02

[03] 2-CAC-ATH-1263-2, Model No. F3, the analyzer was observed indicating upscale.

0 4 | This monitor has a history of similar events involving upscale indications.

05 This event did not affect the health or safety of the public.

06

07

Technical Specifications 3.6.6.4, 6.9.1.9b

Technical Specifications 3.0.0.4, 0.9.1.9B

0 8 7 8

SYSTEM CODE: S F 11

CAUSE CODE: E 12

CAUSE SUBCODE: F 13

COMP. SUBCODE: A 15

VALVE SUBCODE: Z 16

COMPONENT CODE: P I P E X X 14

SEQUENTIAL REPORT NO.: 0 1 6

OCCURRENCE CODE: 0 3 28 29

REPORT TYPE: L 30

REVISION NO.: 0 32

EVENT YEAR: 8 1 21 22

LEAK/REPORT NUMBER: 17

ACTION TAKEN: A 18

EFFECT ON PLANT: Z 20

SHUTDOWN METHOD: Z 21

HOURS: 0 0 0 0 22 27

ATTACHMENT SUBMITTED: Y 23

NPRD-4 FORM SUB.: Y 24

PRIME COMP. SUPPLIER: N 25

COMPONENT MANUFACTURER: B 1 3 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1][0] The analyzer sample inlet rubber tubing became deteriorated and cracked due to age al-

[11] allowing ambient air to enter and mix with the analyzer sample flow. The tubing was re-

1 2 placed and the analyzer calibrated and returned to service. A check of the other sim-

3) Bilateral monitors of both units revealed no problems. Maintenance instructions are being

14 revised to inspect the sample inlet rubber tubing of these monitors on a bi-weekly basis.

FACILITY STATUS				% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	1	28	0	7	2	29	N/A	A	31	Routine Surveillance
7	8	2		10	12	13		44	45	46	60

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

[1] [6] [2] [33] [7] [34]

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	8100000000	

PERSONNEL INJURIES										
NUMBER				DESCRIPTION (41)						
1	8	0	0	0	40					

8		9		11		12	
LOSS OF OR DAMAGE TO FACILITY (43)							
TYPE		DESCRIPTION					
1	9	7	42				
2	8	3	10				

PUBLICITY
 ISSUED DESCRIPTION (45)
 20 N (44)
 7 8 9 10
 8210150308 810227
 PDR ADUCK 05000324
 S PDR
 NRC USE ONLY
 68 69

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521

Facility: BSEP Unit No. 2

Event Date: 2-7-81

Due to a history of similar problems involving these monitors, they will be replaced with others of a more reliable design during a future scheduled outage.

DO NOT SIGN CONTINUOUS MONITORING OXYGEN ANALYZER

Technical Specifications: 3.6.0.4, 6.0.1.1

NAME

EL. WORK NO.

DATE

VAL. SUBJECT

REPORT NO.

DATE

BY

REMARKS

WORK NO.

DATE

BY

PRINCIPAL

COORDINATOR

13/02 13/03 13/04 13/05 13/06 13/07 13/08 13/09 13/10 13/11 13/12

DO NOT SIGN CONTINUOUS MONITORING OXYGEN ANALYZER

DO NOT SIGN CONTINUOUS MONITORING OXYGEN ANALYZER

DO NOT SIGN CONTINUOUS MONITORING OXYGEN ANALYZER

LOCATION OF DEFECT