

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 M I D C C N 1 2 0 0 - 1 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

REPORT SOURCE: L 6 0 5 0 0 0 3 1 7 7 0 4 2 4 8 1 8 0 5 2 2 8 1 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 At 0825 during normal operation, Channel "A" RPS Containment Pressure

3 Trip Unit (T.S. 3.3.1.1), and ESFAS Channel "ZD" Containment Pressure

4 Sensor were placed out of service to replace an E/E converter (T.S.

5 3.3.2.1). Both instruments were returned to service at 0910. The three

6 redundant channels for RPS and ESFAS remained operable during this event.

7 LER's 81-07 and 05000318/81-08 describe similar occurrences.

SYSTEM CODE: I B 11

CAUSE CODE: E 12

CAUSE SUBCODE: E 13

COMPONENT CODE: I N S T R U 14

COMP. SUBCODE: E 15

VALVE SUBCODE: Z 16

LER/RO REPORT NUMBER: 17

EVENT YEAR: 8 1

SEQUENTIAL REPORT NO.: 0 3 0

OCCURRENCE CODE: 0 3

REPORT TYPE: L

REVISION NO.: 0

ACTION TAKEN: A 18

FUTURE ACTION: Z 19

EFFECT ON PLANT: Z 20

SHUTDOWN METHOD: Z 21

HOURS: 0 0 0 0

ATTACHMENT SUBMITTED: N 23

NPRD-4 FORM SUB.: Y 24

PRIME COMP. SUPPLIER: A 25

COMPONENT MANUFACTURER: T 2 8 7 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 Within 24 Hrs. of receiving approved power supply (PS) modifications, iso-

1 lator 1-E/E-5313A (Transmation #230IT) failed upon loss of its +15 PS.

2 The isolator was replaced and will be repaired by its Mfr. Failure may

3 have been induced during modification work. No other modified isolators

4 have failed. No preventive actions are presently deemed necessary.

FACILITY STATUS: E 28

% POWER: 1 0 0 29

OTHER STATUS: NA 30

METHOD OF DISCOVERY: A 31

DISCOVERY DESCRIPTION: Operator Observation 32

ACTIVITY CONTENT: Z 33

RELEASED OF RELEASE: Z 34

AMOUNT OF ACTIVITY: NA 35

LOCATION OF RELEASE: NA 36

PERSONNEL EXPOSURES: 0 0 0 37

TYPE: Z 38

DESCRIPTION: NA 39

PERSONNEL INJURIES: 0 0 0 40

DESCRIPTION: NA 41

LOSS OF OR DAMAGE TO FACILITY: Z 42

DESCRIPTION: NA 43

PUBLICITY: N 44

DESCRIPTION: NA 45

NRC USE ONLY