

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	6	1	7	1	0	1	7	8	2	8	1	0	1	9	8	2	9
60	61								68	69						74	75							80
DOCKET NUMBER											EVENT DATE					REPORT DATE								

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | With the plant in Mode 4 during surveillance testing, containment

0 3 | cooling fan 2E-402 failed to start and was declared inoperable. At this time

0 4 | both containment spray pumps were out of service for flushing of the system.

0 5 | Public health and safety was not affected.

0 6 |

0 7 |

0 8 |

7 8 9

SYSTEM CODE S B 11		CAUSE CODE E 12		CAUSE SUBCODE A 13		COMPONENT CODE Z Z Z Z Z Z 14				COMP. SUBCODE Z 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 2 21 22		SHUTDOWN METHOD 23		SEQUENTIAL REPORT NO. 1 1 4 24 26		OCCURRENCE CODE 0 1 28 29		REPORT TYPE T 30		REVISION NO. 0 32	
ACTION TAKEN A 33		FUTURE ACTION Z 34		EFFECT ON PLANT Z 35		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 41		PRIME COMP. SUPPLIER A 25 43		COMPONENT MANUFACTURER Z 9 9 9 26 44 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The event was due to a faulty breaker for fan 2E-402. The breaker was replaced.

1 1 | A proposed Technical Specification change has been initiated to correct mode

1 2 | applicability inconsistencies between LCO's 3.6.2.1 and 3.6.2.3. This incident

1 3 | was an isolated occurrence and no further corrective action is necessary.

1 4 |

FACILITY STATUS (1) 5 (2) B (28) 0 POWER (29) 0 0 0 (30) NA OTHER STATUS (31) B (32) Surveillance test  
 ACTIVITY CONTENT RELEASED OF RELEASE (1) 6 (2) Z (33) 3 (34) 4 (35) NA AMOUNT OF ACTIVITY (36) NA LOCATION OF RELEASE (37) NA  
 PERSONNEL EXPOSURES NUMBER (1) 7 (2) 0 (3) 0 (4) 0 (38) Z (39) NA DESCRIPTION (40) NA  
 PERSONNEL INJURIES NUMBER (1) 8 (2) 0 (3) 0 (4) 0 (41) NA DESCRIPTION (42) NA  
 LOSS OF OR DAMAGE TO FACILITY TYPE (1) 9 (2) Z (43) NA DESCRIPTION (44) NA  
 PUBLICITY ISSUED (1) 0 (2) 0 (45) NA DESCRIPTION (46) NA  
 8210280086 821019 PDR ADOCK 05000361 S PDR  
 NRC USE ONLY

NAME OF PREPARER

H. B. Ray

PHONE 714/492-7700