

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE 0 1 7 8 L 6 0 5 0 0 0 3 1 8 7 0 9 2 0 8 2 8 1 0 2 0 8 2 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	At 1115, during normal operation, Reactor Protective System Channel
0	3	C trip unit for high pressurizer pressure tripped for no apparent
0	4	reason and was subsequently bypassed (T.S. 3.3.1.1). The trip unit's
0	5	power supply was replaced and the channel returned to service at 1330.
0	6	The three redundant channels remained capable during this event.
0	7	Similar events: 76-7 (U-1)
0	8	

7 8 9

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE			
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24		
		I	A	E		X		I	N	S	T	R	U	P		Z			
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42		
17		8	2	0	4	6	0	3	L		0								
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60		
A	Z	Z		Z		0	0	0	0	N		Y		N		P	3	1	4

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause for this event was a failed low trip bistable power supply

1 1 | (Powermate model #DRA15-.750/15-.750B). Replaced power supply with spare

1 2 | from cabinet, returned failed power supply to vendor for repair; failure

1 3 | cause is unknown. This and similar type failures are being investigated

1 4 | to determine future preventive action; an up-dated report will follow.

FACILITY STATUS				% POWER				OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
1	5	E	28	0	8	6	29	NA				A	31	Operator Observation			
7	8	9		10	11	12	13					45	46	80			

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 10 Z 34 NA

7 8 9 11

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	
7	8	9	11	12	13				80

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 NA

LOSS OF OR DAMAGE TO FACILITY					
TYPE		DESCRIPTION			
1	9	Z	(42)	NA	

7 8 9 10 80

PUBLICITY		ISSUED		DESCRIPTION		NRC USE ONLY	
2	0	N	44	B210280141 B21020 PDR ADOCK 05000318 S PDR			
7	8	9	10	68		69	80

NAME OF PREPARER J. S. Lagiewski/J. W. Raynor

PHONE: 301-269-4747/4713