


**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	J	S	G	S	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	14						15	25										26	30					57	CAT	58		
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE									

CON'T

0 1  
7 8

REPORT SOURCE 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

DOCKET NUMBER 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

EVENT DATE 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

REPORT DATE 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On October 5, 1982, during a containment surveillance, a small service water leak of approximately 1.0 GPM was discovered on No. 21 Containment Fan Coil Unit (CFCU). The unit was isolated and immediate notification of the NRC was performed. No. 21 CFCU was declared inoperable; Action Statement 3.6.2.3a was already in force as of 1653 hours, October 4, 1982, when the CFCU had been taken out of service for maintenance. Both containment spray systems were operable. The event constituted abnormal degradation of containment in accordance with Technical Specification 6.9.1.8.c. (82-111, 82-109, 82-101, 82-100, 82-093)

80

09	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE	17	LER RO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.	ATTACHMENT SUBMITTED	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
09	S B 11	C 12	Z 13	H T E X C H 14	C 15	Z 16	17	LER RO REPORT NUMBER	8 2 21 22	1 1 2 24 26	0 1 28 29	T 30	0 32	Y 41	A 43	W 1 2 0 44 47

23 34 35 36 37 40 41 42 43 44 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The leakage was from a flange in the service water piping; a blank had been removed

1 1 following Belzona repair of a previous leak. Adverse working conditions in the

1 2 vicinity of the CFCU make torquing and alignment of the flange difficult. The flange

1 3 was retorqued, the leakage was stopped and the action statement terminated.

1 4

7 8 9

FACILITY STATUS (1 5) E (28) % POWER (0 8 2) (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (A) (31) DISCOVERY DESCRIPTION (32) Operator Observation

7 8 9 10 11 12 13 14 15 16 17 18 19 20

ACTIVITY CONTENT RELEASED OF RELEASE (1 6) Z (33) Z (34) NA AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20

PERSONNEL EXPOSURES NUMBER (1 7) 0 0 0 (37) Z (38) NA DESCRIPTION (39)

7 8 9 10 11 12 13 14 15 16 17 18 19 20

PERSONNEL INJURIES NUMBER (1 8) 0 0 0 (40) NA DESCRIPTION (41)

7 8 9 10 11 12 13 14 15 16 17 18 19 20

LOSS OF OR DAMAGE TO FACILITY TYPE (1 9) Z (42) NA DESCRIPTION (43)

7 8 9 10 11 12 13 14 15 16 17 18 19 20

PUBLICITY ISSUED (2 0) N (44) NA DESCRIPTION (45) 8210280156 821015 PDR ADOCK 05000311 S PDR

7 8 9 10 11 12 13 14 15 16 17 18 19 20

NRC USE ONLY

NAME OF PREPARER R. Frahm

PHONE: 609/935-6000 Ext 3078