

Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

October 19, 1982


Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-027/03L-0
ER 100450 FILE 841-23
PLA-1354

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-027/03L-0. This event was determined to be reportable, per Technical Specification 6.9.1.9.b, in that two suppression chamber - drywell vacuum breakers were declared inoperable due to apparent false position indications.


H.W. Keiser

Superintendent of Plant-Susquehanna

DGM/cw

Attachment

cc: A. Schwencer
Division of Licensing,
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Ter