

LICENSEE EVENT REPORT

036716

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 M D C C N 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

1 REPORT SOURCE L 6 0 5 0 0 0 3 1 7 7 0 3 1 1 8 1 8 0 4 1 0 8 1 9
8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 During normal power operation of Unit 1 and Mode 3 operation of Unit 2
3 at 1500; experienced a failure of 1 containment hydrogen analyzer (0-AE-
4 6519), a degradation of the requirements of T.S. 3.6.5.1. The analyzer
5 was restored to service at 2030. The redundant hydrogen analyzer remain-
6 ed operable during this event. This event had no impact on the public
7 health or safety. This has not been a repetitive event.

8 9
17 LER/RO REPORT NUMBER 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15
SEQUENTIAL REPORT NO. 16 OCCURRENCE CODE 17 REPORT TYPE 18 REVISION NO. 19
ACTION TAKEN 20 FUTURE ACTION 21 EFFECT ON PLANT 22 SHUTDOWN METHOD 23 HOURS 24 ATTACHMENT SUBMITTED 25 NPRO-4 FORM SUB. 26 PRIME COMP. SUPPLIER 27 COMPONENT MANUFACTURER
G 18 Z 19 Z 20 Z 21 Z 22 0 0 0 0 23 N 24 Y 25 A 26 D 0 9 6 27

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The Analyzer (Delphi No. B1A-1A1E) "Zero" adjustment potentiometer was
11 found defective during operation. A replacement part was not available;
12 the Analyzer was replaced with a spare. The failed Analyzer will be re-
13 paired upon receipt of a replacement part. The Analyzer is surveillance
14 tested quarterly. No further preventive action is deemed necessary.

15 FACILITY STATUS 16 % POWER 17 OTHER STATUS 18 METHOD OF DISCOVERY 19 DISCOVERY DESCRIPTION 20
E 28 1 0 0 29 NA 30 A 31 Operator Observation 32
16 ACTIVITY CONTENT 17 RELEASED OF RELEASE 18 AMOUNT OF ACTIVITY 19 LOCATION OF RELEASE 20
Z 33 Z 34 NA 35 NA 36
17 PERSONNEL EXPOSURES 18 NUMBER 19 TYPE 20 DESCRIPTION 21
0 0 0 37 Z 38 NA 39
18 PERSONNEL INJURIES 19 NUMBER 20 DESCRIPTION 21
0 0 0 40 NA 41
19 LOSS OF OR DAMAGE TO FACILITY 20 TYPE 21 DESCRIPTION 22
Z 42 NA 43
20 PUBLICITY 21 ISSUED 22 DESCRIPTION 23
N 44 NA 45

NRC USE ONLY

R. L. Wenderlich/P G. Pizzo

12011 260 4775 11706

8210280313 810410
PDR ADOCK 05000317
S PDR