



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 28, 1982

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Reduced DC Electrical Reserves
for Division I ECCS System
Due to Improper Charger
Maintenance Instruction
Reference: LER 82-078/03 L-0
AECM-82/512

Battery Surveillance Procedure 06-EL-1L11-W-0001 revealed the voltage on the Division I DC Supply to be 121.7 volts DC. This resulted in a reduction in the DC electrical reserve for the Division I ECCS System. This event is being reported under T.S.3.8.2.2, T.S.4.8.2.1.a.2, and pursuant to T.S.6.9.1.13.b. Attached is LER 82-078/03 L-0.

Yours truly,

[Signature]
For J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211040069 821028
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22