



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 28, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1

Docket No. 50-416

License No. NPF-13

File 0260/L-835.0

Loss of Control Room

Indication on Chilled Water

Aux. Bldg. Isolation Valve

1P71F301 During Routine

Surveillance

Reference: LER 82-084/03 L-0

AECM-82/514

During Non-Nuclear Heatup with the Plant in Operational Mode 3, Control Room indication was lost on Chilled Water Auxiliary Building Isolation Valve 1P71F301 when the valve was cycled during routine surveillance. This event is being reported per T.S.3.6.6.2 and 6.9.1.13.b. Attached is LER 82-084/03 L-0.

Yours truly,

J. P. McGaughy, Jr.
For J. P. McGaughy, JR.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211040113 821028
PDR ADDCK 05000416
S PDR

Middle South Utilities System

OFFICIAL COPY

IE 22