

LICENSEE EVENT REPORT

UPDATE REPORT:

Previous Report Date: 8-27-81

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NCBEP 22 00-000000-0003 411111 45
7 8 9 14 15 25 26 30 57 CAT 58

CONT

01 REPORT SOURCE L 6 0500-0324 7 072881 8 102582 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing the monthly load test of No. 4 diesel generator, PT-12.2d, a loud,
03 unusual noise was heard from the diesel and the diesel generator would not assume a
04 load > 1,000 kw. On July 30, 1981, when an attempt was made to start No. 4 diesel
05 generator for operability testing, it would not start. Neither of these events
06 affected the health and safety of the public.

07

08 Technical Specifications 3.8.1.1, 6.9.1.9b

7 8 9 80

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
E E 11 X 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 1 0 6 9 0 3 L 1
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 X 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 A 25 X 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Immediately following each event, the diesel was restarted and verified operable.
11 In addition, after the July 28, 1981, event PT-12.2d was satisfactorily completed.
12 An investigation of each event failed to determine a cause of each problem. Operation
13 of the diesel on at least a monthly basis since then has not seen the problems reoccur.

14

7 8 9 80

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
F 28 0 4 1 29 NA B 31 Periodic Test
7 8 9 10 12 13 44 45 46 80

16 RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 80

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 NA
7 8 9 10 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42
7 8 9 10 80

20 PUBLICITY ISSUED DESCRIPTION (45)
N 44 NA
7 8 9 10 68 69 80

NAME OF PREPARER R. M. Poulk, Jr.

PHONE: 919-457-9521