LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1)   (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	LICENSEE CODE (2)	T N S N P 1
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
01 (CON'T)	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 3 2 7
	EVENT DATE (8)	0 9 2 9 8 2
	REPORT DATE (9)	1 0 2 7 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With unit 1 in mode 5 (0% power, 115 degrees F, 0 psig) at 0300 CST on 09/29/82
03 the auxiliary building ventilation radiation monitor was declared inoperable due to
04 loss of sample flow. This event required entry into action statements 41, 42, and
05 44 of LCO 3.3.3.10. There was no effect upon public health and safety. Previous
06 occurrences - none.
07
08

Line	Field	Value
09	SYSTEM CODE (11)	M B
	CAUSE CODE (12)	E
	CAUSE SUBCODE (13)	F
	COMPONENT CODE (14)	X X X X X X
	COMP. SUBCODE (15)	Z
	VALVE SUBCODE (16)	Z
(17) LER/RO REPORT NUMBER	EVENT YEAR	8 2
		—
	SEQUENTIAL REPORT NO.	1 1 4
		/
	OCCURRENCE CODE	0 3
	REPORT TYPE	L
		—
	REVISION NO.	0
	ACTION TAKEN (18)	A
	FUTURE ACTION (19)	Z
	EFFECT ON PLANT (20)	Z
	SHUTDOWN METHOD (21)	Z
	HOURS (22)	0 0 0 0
	ATTACHMENT SUBMITTED (23)	N
	NPRD-4 FORM SUB. (24)	N
	PRIME COMP. SUPPLIER (25)	L
	COMPONENT MANUFACTURER	X 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Investigation revealed that the sample flow vacuum pump drive belt broke due to
11 normal wear on the belt. The belt was replaced and the monitor returned to service
12 at 0557 on 09/29/82. No further action is planned.
13
14

Line	Field	Value
15	FACILITY STATUS (28)	G
	% POWER (29)	0 0 0
	OTHER STATUS (30)	NA
	METHOD OF DISCOVERY (31)	B
	DISCOVERY DESCRIPTION (32)	Operator observation
16	ACTIVITY RELEASED (33)	Z
	CONTENT OF RELEASE (34)	Z
	AMOUNT OF ACTIVITY (35)	NA
	LOCATION OF RELEASE (36)	NA
17	PERSONNEL EXPOSURES NUMBER (37)	0 0 0
	TYPE (38)	Z
	DESCRIPTION (39)	NA
18	PERSONNEL INJURIES NUMBER (40)	0 0 0
	DESCRIPTION (41)	NA
19	LOSS OF OR DAMAGE TO FACILITY (43) TYPE (42)	Z
	DESCRIPTION	NA
20	PUBLICITY ISSUED (44)	N
	DESCRIPTION (45)	NA
	NRC USE ONLY	

Name of Preparer: H. R. Rogers /M. R. Harding Phone: (615) 751-0349