

OPERATING DATA REPORT

DOCKET NO. 50-289
 DATE October 15, 1981
 COMPLETED BY C. W. Smyth
 TELEPHONE (717) 948-8551

OPERATING STATUS

1. Unit Name: Three Mile Island Nuclear Station, Unit I
2. Reporting Period: September, 1981
3. Licensed Thermal Power (MWt): 2535
4. Nameplate Rating (Gross MWe): 871
5. Design Electrical Rating (Net MWe): 819
6. Maximum Dependable Capacity (Gross MWe): 840
7. Maximum Dependable Capacity (Net MWe): 776
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720.</u>	<u>6581.</u>	<u>62064.</u>
12. Number Of Hours Reactor Was Critical	<u>0.0</u>	<u>0.0</u>	<u>31731.8</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>839.5</u>
14. Hours Generator On-Line	<u>0.0</u>	<u>0.0</u>	<u>31180.9</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0.0</u>	<u>0.0</u>	<u>76531071.</u>
17. Gross Electrical Energy Generated (MWH)	<u>0.</u>	<u>0.</u>	<u>25484330.</u>
18. Net Electrical Energy Generated (MWH)	<u>0.</u>	<u>0.</u>	<u>23840053.</u>
19. Unit Service Factor	<u>0.0</u>	<u>0.0</u>	<u>50.2</u>
20. Unit Availability Factor	<u>0.0</u>	<u>0.0</u>	<u>50.2</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0.0</u>	<u>0.0</u>	<u>48.9</u>
22. Unit Capacity Factor (Using DER Net)	<u>0.0</u>	<u>0.0</u>	<u>46.9</u>
23. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>43.0</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-289

UNIT TMI-I

DATE October 15, 1981

COMPLETED BY C. W. Smyth

TELEPHONE (717) 948-8551

MONTH September, 1981

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>0</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH September, 1981

DOCKET NO. 50-289
UNIT NAME TMI-I
DATE October 15, 1981
COMPLETED BY C. W. Smyth
TELEPHONE (717)948-8551

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
1	9/1/81	F	720	D	1				Regulatory Restraint Order

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵
Exhibit I - Same Source

MONTHLY OPERATING REPORT

Operating Summary

Hot Functional Testing was being completed at the beginning of this report period. Testing performed was described in the August Operating Report. On September 9, 1981, the Unit was returned to cold shutdown where it has remained the remainder of this report period.

Major Safety Related Maintenance

While operating at 2155 psi, 532°F, Decay Heat Valve, DH-V-1, developed a small seal ring leak. Repair to the valve was performed by re-injecting furmanite into the seal ring area. The leakage from the seal ring area was reduced. The leakage was stopped when the system was placed in-service.

REFUELING INFORMATION REQUEST

1. Name of Facility:

Three Mile Island Nuclear Station, Unit I

2. Scheduled date for next refueling shutdown:

Unknown

3. Scheduled date for restart following refueling:

Unknown

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If answer is yes, in general, what will these be?

If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?

If no such review has taken place, when is it scheduled?

Amendment No. 50, Cycle 5 reload, was approved on 3-16-79.

5. Scheduled date (s) for submitting proposed licensing action and supporting information:

N/A

6. Important licensing considerations associated with refueling, e.g. new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

N/A

7. The number of fuel assemblies (a) in the core, and (b) in the spent fuel storage pool:

(a) 177

(b) 208

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:

The present licensed capacity is 752. There are no planned increases at this time.

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:

1986 is the last refueling discharge which allows full core off-load capacity (177 fuel assemblies).