

LICENSEE EVENT REPORT

Attachment to AECM-82/475

Page 1 of 1

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M S G G S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T

REPORT SOURCE

L 6 0 5 0 0 0 4 1 6 7 0 9 1 5 8 2 8 1 0 1 3 8 2 9
60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During routine surveillance in preparing for non nuclear heatup (Reactor Recirculation
03 Pump for Heatup), it was discovered that Steam Tunnel Fire Door 1A230 was open with no
04 fire watch stationed. The door could not be closed due to the cables (being used for
05 maintenance activity in the Steam Tunnel) installed in the doorway. T.S.3.7.7 requires
06 all fire rated assemblies to be operational at all times or a fire watch stationed
07 until the fire rated assemblies are operational. There was no release of radioactivity,
08 effect upon public health or safety, or a threat to plant safety.
7 8 9 80

09 A B 11 A 12 C 13 X X X X X X 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 2 21 22 23 0 7 5 24 26 27 9 9 28 29 9 30 31 0 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 Z 19 Z 20 Z 21 0 0 0 0 40 N 23 N 24 Z 25 Z 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The fire door was required to be open to allow maintenance work in the steam tunnel.
11 An hourly fire watch was established as required by T.S.3.7.7. The fire watch was
12 maintained for 13 days and 21 hours until the work was complete. Upon completion of
13 the work, the fire door was secured. No further action was required.
7 8 9 80

14
7 8 9 80
FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
1 5 B 28 0 0 0 29 NA B 31 Routine Surveillance
7 8 9 10 12 13 44 45 46 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
1 6 Z 33 Z 34 NA 44 45 NA 80
7 8 9 10 11 44 45 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
1 7 0 0 0 37 Z 38 NA
7 8 9 11 12 13 80
PERSONNEL INJURIES NUMBER DESCRIPTION 41
1 8 0 0 0 40 NA
7 8 9 11 12 80
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
1 9 Z 42 NA
7 8 9 10 80
PUBLICITY ISSUED DESCRIPTION 45
2 0 N 44 NA
7 8 9 10 80
8211040291 821025
PDR ADDOCK 05000416
S PDR
NRC USE ONLY
58 69 80

NAME OF PREPARER Original Signed by W. H. Chenault

PHONE: