



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 28, 1982

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Spurious Smoke Detector Alarm
Reference: LER 82-096/03 L-0
AECM-82/513

On October 1, 1982, fire zone 2-04 was deactivated in the Security and Fire Protection Computer due to inability to reset a spurious smoke detector alarm. This report is being submitted per T.S.3.3.7.9.a. Attached is LER 82-096/03 L-0.

Yours truly,

[Signature]
FOR J.P. McGaughy JR.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

8211040313 821028
PDR ADOCK 05000416
S PDR

IG 22