

## U.S. NUCLEAR REGULATORY COMMISSION

## LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT  
/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/9/ (7) /1/0/1/2/8/2/ (8) /1/0/2/7/8/2/ (9)  
SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On October 12, 1982, while in Mode 1, Intermediate Range Channel N-35 failed low./  
/0/3/ / Since reactor power was greater than 5% no further actions were required until /  
/0/4/ / shutdown. Consequently, the public health and safety were not affected. This /  
/0/5/ / event is contrary to T.S. 3.3.1 and reportable pursuant to T.S. 6.9.1.9.b. There/  
/0/6/ / are no generic implications to this event and no further actions are required. /  
/0/7/ /  
/0/8/ /

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
/0/9/ /I/A/ (11)	/E/ (12)	/E/ (13)	/I/N/S/T/R/U/ (14)	/Y/ (15)	/Z/ (16)
LER/RO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.

(17) /8/2/ /-/ /0/6/4/ / /0/3/ /L/ /-/ /0/  
ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT  
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER  
/A/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/ (26)

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The cause for Intermediate Range Channel N-35 failing low is the result of a /  
/1/1/ / failed Log Current Amplifier Module. The module was replaced, tested satisfact- /  
/1/2/ / orily and restored to service. /  
/1/3/ /  
/1/4/ /

FACILITY STATUS	%POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
/1/5/ /E/ (28)	/1/0/0/ (29)	/ NA / (30)	/A/ (31)	/ Operator Observation /

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
/1/6/ /Z/ (33)	/Z/ (34)	/ NA /	/ NA /

PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION (39)
/1/7/ /0/0/0/ (37)	/Z/ (38)	/ NA /

PERSONNEL INJURIES NUMBER	DESCRIPTION (41)
/1/8/ /0/0/0/ (40)	/ NA /

LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION (43)
/1/9/ /Z/ (42)	/ NA /

PUBLICITY ISSUED	DESCRIPTION (45)
/2/0/ /N/ (44)	/ NA /

NRC USE ONLY

NAME OF PREPARER W. R. CARTWRIGHT

PHONE (703) 894-5151