



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 25, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Correction of Design Change
Package 82-4145 Issue Date
Reference: LER 82-085/03 L-0
AECM-82/499

Attached is corrected LER 82-085/03 L-0. The issue date of the Design Change Package 82-4145 has been corrected to September 4, 1982 vice September 24, 1982.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211040440 821025
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IC 22

82 OCT 27 A10:21
USNR REGIONAL
ATLANTA, GEORGIA



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 18, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Secondary Containment
Integrity - Three Secondary
Containment Penetrations
Opened for Cable Routing
Reference: LER 82-085/03 L-0
AECM-82/486

While performing work under Design Change Package 82-4145 issued on September 4, 1982 for completion of the original construction of the heat tracing portion of the Drywell Monitoring System, three secondary containment penetrations were opened for cable routing. This report is being submitted per T.S.6.9.1.13.b and T.S.3.7.7. Attached is LER 82-085/03 L-0.

Yours truly,

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8210220408
Member Middle South Utilities System

JDR

FILE COPY