

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80									
0 1 2 3 4 5 6 7 8 9 N C B E P 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58									
CON'T 0 1 2 3 4 5 6 7 8 9 REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 1 0 0 9 8 2 8 1 1 0 4 8 2 9 DOCKET NUMBER EVENT DATE REPORT DATE									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10									
0 2 During a reactor startup, the following control rod positions had no indications									
0 3 at the identified positions: rod 34-39 (03, 06, 48); rod 06-11 (48); rod 14-11 (30);									
0 4 rod 02-31 (00); rod 18-35 (19). In each case, the health and safety of the public was									
0 5 not affected.									
0 6 Technical Specifications 3.1.3.7, 6.9.1.9b									
0 7									
0 8									
0 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 SYSTEM CAUSE CAUSE COMPONENT COMP. VALVE CODE CODE SUBCODE CODE SUBCODE SUBCODE I B 11 E 12 A 13 Z Z Z Z Z Z 14 Z 15 Z 16 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO. 8 2 1 0 5 0 3 L 0 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER X 18 X 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 G 0 8 0 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27									
1 0 Defective position reed switches in the subject rods are believed to be the cause									
1 1 of the indication problems. These switches will be repaired during the upcoming									
1 2 refueling outage. As these failures do not constitute a safety hazard and do occur									
1 3 occasionally, no additional actions are required.									
1 4									
FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32 C 28 0 0 0 29 NA A 31 Operational Event ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36 Z 33 Z 34 NA PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 0 0 0 37 Z 38 NA PERSONNEL INJURIES NUMBER DESCRIPTION 41 0 0 0 40 NA LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43 Z 42 NA PUBLICITY ISSUED DESCRIPTION 45 N 44 8211100297 821104 PDR ADOCK 05000325 S PDR NRC USE ONLY 68 69 70									
NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521									