

APPROVED BY OMB
3150-0011
EXPIRES 4-30-82

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	S	C	V	C	S	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	0	0	0	4			5			
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT		58

01 REPORT SOURCE L 6 0 5 0 0 3 9 5 7 1 0 0 8 8 2 8 1 1 0 5 8 2 9

0 2 | On October 8, 1982, while performing Surveillance Test Procedure (STP) 303.006
0 3 | on the "B" Steam Generator Main Steam Line Pressure Instrumentation, a pressure
0 4 | bistable failed to change output state when varying the input about the trip and
0 5 | reset points. No adverse condition resulted as appropriate measures were
0 6 | established to comply with the applicable Technical Specification Action
0 7 | Statement.
0 8 |

0 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
7	8	I	B	11	E	12	G	13	I	N	S	T	R	U	14	V	15	Z	16
		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
17		LER/RO REPORT NUMBER		8 2		0 1 8		/ 0 3		1		0							
21		22		23		24		25		26		27		28		29		30	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		APRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
A		Z		Z		Z		0 0 0 0		Y		N		N		B 0 8 0		26	
18		19		20		21		22		23		24		25		26		27	

1 0 Investigation revealed that a printed circuit logic card had failed. This card

1 1 was replaced, and the Surveillance Test Procedure was performed satisfactory.

1 2 The system was returned to operable status on October 8, 1982. The licensee

1 3 plans no further actions for this event.

1 4

8 9
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 [B] (28) 0 0 0 (29) N/A [B] (31) Surveillance Test Observation

7 8 9 10 11 12 13 14 15 16 17 18

ACTIVITY CONTENT AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

RELEASED OF RELEASE

1 6 [Z] (33) [Z] (34) N/A N/A

7 8 9 10 11 12 13 14 15 16 17 18

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38	N/A	

PERSONNEL INJURIES		NUMBER		DESCRIPTION		(41)	
1	8	0	0	0	(40)	N/A	

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (43)

1 9 Z (42) 8211100299 821105

PDR ADDCK 05000395
 S
 PDR
 NRC USE ONLY

H. C. Fields

PHONE: (803) 345-5209