



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 5, 1982 NOV 8 P 3: 00

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Failure to Satisfy
Requirements of
T.S.3.8.1.1.f
Reference: LER 82-103/01 T-0
AECM-82/531

During Shutdown, while reviewing documentation declaring HPCS Division III Diesel Generator inoperative, it was discovered the requirements of T.S.3.8.1.1.f were not satisfied. Attached is LER 82-103/01 T-0.

Yours truly,

LFD
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8211100335 821105
PDR ADDCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

1E 22