(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A L J M F 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 4 (7) | 1 0 1 3 8 2 (8) | 1 1 0 5 8 2 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 0730 on 10/13/82 during the performance of FNP-2-STP-15.0 (Containment Air Lock Door
0 3 Seal Operability Test), the containment auxiliary personnel hatch was declared inoper-
0 4 able when it failed to meet the leakage acceptance criteria on the outer door. Tech.
0 5 Spec. 3.6.1.3, in part, requires the auxiliary personnel hatch to be operable. Tech.
0 6 Spec. action statement requirements were met. Health/safety of the public was not
0 7 affected.
0 8
7 8 9 80

SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
0 9 | S D (11) | E (12) | C (13) | P E N E T R (14) | A (15) | Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
8 2 — 0 4 2 / 0 3 L — 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS (22) | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
A (18) | Z (19) | Z (20) | Z (21) | 0 0 0 0 | N (23) | N (24) | A (25) | C 1 3 0 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was due to worn gaskets on the auxiliary personnel hatch outer door. The
1 1 gaskets were replaced and following the satisfactory completion of FNP-2-STP-15.0
1 2 (Containment Air Lock Door Seal Operability Test), the personnel hatch was declared
1 3 operable at 1100 on 10/13/82.
1 4
7 8 9 80

FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32)
1 5 | E (28) | 1 0 0 (29) | NA | B (31) | Surveillance Test
7 8 9 10 12 13 44 45 46 80

ACTIVITY RELEASED | CONTENT OF RELEASE | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36)
1 6 | Z (33) | Z (34) | NA | NA
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES
NUMBER | TYPE | DESCRIPTION (39)
1 7 | 0 0 0 (37) | Z (38) | NA
7 8 9 11 12 13 80

PERSONNEL INJURIES
NUMBER | DESCRIPTION (41)
1 8 | 0 0 0 (40) | NA
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE | DESCRIPTION
1 9 | Z (42) | NA
7 8 9 10 80

PUBLICITY
ISSUED | DESCRIPTION (45)
2 0 | N (44) | NA
7 8 9 10 68 69 80

8211100387 821105
PDR ADOCK 05000364
S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III PHONE (205) 899-5156

GPO 917-926