



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

November 5, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

02 NOV 8 3:00

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Only One of Two Required ECCS
Systems Operable Due to
HPCS Pump Declared
Inoperable
Reference: LER 82-097/03 L-0
AECM-82/530

With the plant in Cold Shutdown, the HPCS Pump was declared inoperable due to an engineering review of an incident which occurred on October 2, 1982. This incident involved an incorrect valve lineup during the performance of a routine surveillance of the HPCS System. Attached is LER 82-097/03 L-0 with supplemental information.

Yours truly,

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY
LE 22