



Carolina Power & Light Company

NOV 08 1982

Office of Nuclear Reactor Regulation
ATTN: Mr. D. B. Vassallo, Chief
Operating Reactors Branch No. 2
United States Nuclear Regulatory Commission
Washington, D.C. 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
REQUEST FOR LICENSE AMENDMENT
CORE SPRAY SYSTEM SPECIAL TEST EXCEPTION

Dear Mr. Vassallo:

SUMMARY

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, Carolina Power & Light Company (CP&L) hereby requests revisions to the Technical Specifications (TS) for the Brunswick Steam Electric Plant, Unit Nos. 1 and 2. These revisions concern the adoption of a new Special Test Exception relating to the 92-day interval core spray system flow test required by Technical Specification 4.5.3.1.c.1.

DISCUSSION

A review of the outage schedule for the upcoming Brunswick-1 refueling outage has determined that, due to the work requirements of the outage, extenuating plant conditions will exist which may preclude the timely performance of core spray system surveillance testing required by Specification 4.5.3.1.c.1. A proposed Special Test Exception is provided in Attachment 1 which includes surveillance testing requirements to be used during the specified plant outage condition. A discussion of the outage work constraints and the technical basis for the proposed revisions is provided in Attachment 2.

ADMINISTRATIVE INFORMATION

Enclosed are TS pages with the proposed revisions indicated by vertical lines in the right-hand margins. We have evaluated this request in accordance with the criteria in 10 CFR 170.22 and have determined that this submittal constitutes a Class III and a Class I license amendment request for Brunswick-1 and Brunswick-2, respectively. Therefore, our check for \$4,400.00 is enclosed in payment of the required fees.

Due to the constraints on outage work imposed by the existing Technical Specification requirements, we request your early review of this submittal. Approval of this submittal is requested by January 14, 1983 to avoid significant impact of these constraints on Mark I torus work.

A001


w/check:

\$4400.00

8211150623 821108
PDR AD0CK 05000324
P PDR

Should you have any questions concerning this submittal, please contact our staff.

Yours very truly,




L. W. Eury
Senior Vice President
Power Supply

WRM/mag (5654C4T6)

Enclosures

cc: Mr. D. O. Myers (NRC-BSEP)
Mr. J. P. O'Reilly (NRC-RII)
Mr. J. A. Van Vliet (NRC)

L. W. Eury, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.


Notary (Seal)

My commission expires: OCT 04 1986

