

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

October 15, 1982

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:


BELLEFONTE NUCLEAR PLANT UNIT 1 - SUPPLEMENTAL RESPONSE TO VIOLATION
50-438/82-06-11 - REACTOR BUILDING SPRAY FLUSH

This is in response to F. S. Cantrell's letter dated April 1, 1982, report numbers 50-438/82-06, 50-439/82-06, concerning activities at the Bellefonte Nuclear Plant which appeared to have been in violation of NRC regulations. The previous response to this violation was submitted on April 30, 1982. As discussed with C. Burger by telephone on October 1, 1982, the date of October 1, 1982 for completion of corrective actions indicated in our response on this matter was not met. TVA's initial attempts to manually clean the reactor building spray header proved to be insufficient. A system reflush has been determined to be necessary to obtain Class B cleanliness. Corrective action on this matter will now be complete on or before March 1, 1983.

If you have any questions concerning this matter, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8211150636 821101
PDR ADOCK 05000438
G PDR

OFFICIAL COPY